



NOTES:

CHECKED BY:	
APPROVED BY:	
ORIG E.O.	2866
	07/06/94
CHG E.O.	5495
	2/19/16
<i>Raypak</i>	

* REFER TO INSTALLATION/OPERATING INSTRUCTIONS AND WIRING DIAGRAM SUPPLIED WITH VENT DAMPER.

** PUMP DELAY 5 MINUTES.

IF ANY OF THE ORIGINAL WIRE AS SUPPLIED WITH THE BOILER MUST BE REPLACED, IT MUST BE REPLACED WITH 105°C WIRE OR ITS EQUIVALENT, AND 150°C AS NOTED.

**WIRE DIAGRAM IID
FIRING MODE - ON/OFF**

BOILER INPUTS: 42,000 THRU 66,000 BTUH

BOILER SIZE: **42-66**

BOILER TYPE: **H4**

KEY	
—	24V 105°C
- - -	24V 150°C
—	120V 105°C
- - -	120V 150°C
○	WIRE NUT
⊕	GROUND
⊖	THERMOSTAT
BK	- BLACK
BR	- BROWN
R	- RED
O	- ORANGE
Y	- YELLOW
G	- GREEN
BL	- BLUE
V	- VIOLET
W	- WHITE