
INSTALLATION INSTRUCTIONS

PACKAGE HEAT PUMPS FEATURING EARTH-FRIENDLY R-410A REFRIGERANT

RQPM 14 SEER SERIES – (2 - 5 TONS) RQNM 13 SEER SERIES – (2 - 5 TONS)





RECOGNIZE THIS SYMBOL AS AN INDICATION OF IMPORTANT SAFETY INFORMATION!

WARNING

THESE INSTRUCTIONS ARE INTENDED AS AN AID TO QUALIFIED, LICENSED SERVICE PERSONNEL FOR PROPER INSTALLATION, ADJUSTMENT AND OPERATION OF THIS UNIT. READ THESE INSTRUCTIONS THOROUGHLY BEFORE ATTEMPTING INSTALLATION OR OPERATION. FAILURE TO FOLLOW THESE INSTRUCTIONS MAY RESULT IN IMPROPER INSTALLATION, ADJUSTMENT, SERVICE OR MAINTENANCE POSSIBLY RESULTING IN FIRE, ELECTRICAL SHOCK, PROPERTY DAMAGE, PERSONAL INJURY OR DEATH.





DO NOT DESTROY THIS MANUAL

PLEASE READ CAREFULLY AND KEEP IN A SAFE PLACE FOR FUTURE REFERENCE BY A SERVICEMAN

TABLE OF CONTENTS

I.	Safety Information	3
II.	Introduction	4
III.	Checking Product Received	7
IV.	Equipment Protection	7
V.	Installation	7
	A. General	7
	1. Pre-Installation Check Points	7
	2. Location	7
	B. Outside Slab Installation	8
	C. Clearances	8
	D. Rooftop Installation	9
VI.	Ductwork	9
VII.	Filters	9
VIII.	Condensate Drain, Indoor Coil	9
IX.	Condensate Drain, Outdoor Coil	10
Χ.	Electrical Wiring	10
	A. Power Wiring	10
	B. Electric Heater Kit Instructions	10
	C. Control Wiring	11
	D. Internal Wiring	11
	E. Grounding	11
	F. Thermostat	12
XI.	Indoor Air Flow Data	12
XII.	Pre-Start Check	12
XIII.	Startup	12
XIV.	Operation	13
XV.	Auxiliary Heat	13
XVI.	Demand Defrost Control	14
XVII.	General Data	15-20
XVIII.	Miscellaneous	
	Electrical and Physical Data	21-22
	Airflow Performance	23-26
	Electric Heater Kit	27-30
	Wiring Diagram	31-34
	Charge Charts	35-40

[▶] Installation instructions are updated on a regular basis. This is done as product changes occur or if new information becomes available. In this publication, an arrow (▶) denotes changes from the previous edition or additional new material.

I. SAFETY INFORMATION

A WARNING

THESE INSTRUCTIONS ARE INTENDED AS AN AID TO QUALIFIED, LICENSED SERVICE PERSONNEL FOR PROPER INSTALLATION, ADJUSTMENT AND OPERATION OF THIS UNIT. READ THESE INSTRUCTIONS THOROUGHLY BEFORE ATTEMPTING INSTALLATION OR OPERATION. FAILURE TO FOLLOW THESE INSTRUCTIONS MAY RESULT IN IMPROPER INSTALLATION, ADJUST-MENT, SERIVICE OR MAINTENANCE POSSIBLY RESULTING IN FIRE, ELECTRI-CAL SHOCK, PROPERTY DAMAGE, PERSONAL INJURY OR DEATH.

A WARNING

PROPOSITION 65: THIS APPLIANCE CONTAINS FIBERGLASS INSULATION. RESPIRABLE PARTICLES OF FIBERGLASS ARE KNOWN TO THE STATE OF CALIFORNIA TO CAUSE CANCER.

WARNING

THE MANUFACTURER'S WARRANTY DOES NOT COVER ANY DAMAGE OR DEFECT TO THE HEAT PUMP CAUSED BY THE ATTACHMENT OR USE OF ANY COMPONENTS, ACCESSORIES OR DEVICES (OTHER THAN THOSE AUTHO-RIZED BY THE MANUFACTURER) INTO, ONTO OR IN CONJUNCTION WITH THE HEAT PUMP. YOU SHOULD BE AWARE THAT THE USE OF UNAUTHORIZED COMPONENTS, ACCESSORIES OR DEVICES MAY ADVERSELY AFFECT THE OPERATION OF THE HEAT PUMP AND MAY ALSO ENDANGER LIFE AND PROPERTY. THE MANUFACTURER DISCLAIMS ANY RESPONSIBILITY FOR SUCH LOSS OR INJURY RESULTING FROM THE USE OF SUCH UNAUTHO-RIZED COMPONENTS, ACCESSORIES OR DEVICES.

A WARNING

DISCONNECT ALL POWER TO THE UNIT BEFORE STARTING MAINTE-NANCE. FAILURE TO DO SO CAN RESULT IN SEVERE ELECTRICAL SHOCK OR DEATH

▲ WARNING

DO NOT, UNDER ANY CIRCUMSTANCES, CONNECT RETURN DUCTWORK TO ANY OTHER HEAT PRODUCING DEVICE SUCH AS A FIREPLACE INSERT, STOVE, ETC. UNAUTHORIZED USE OF SUCH DEVICES MAY RESULT IN FIRE, CARBON MONOXIDE POISONING, EXPLOSION, PROPERTY DAMAGE, SEVERE PERSONAL INJURY OR DEATH.

WARNING

TURN OFF ELECTRIC POWER AT THE FUSE BOX OR SERVICE PANEL BEFORE MAKING ANY ELECTRICAL CONNECTIONS.

ALSO, THE GROUND CONNECTION MUST BE COMPLETED BEFORE MAKING LINE VOLTAGE CONNECTIONS. FAILURE TO DO SO CAN RESULT IN ELECTRI-CAL SHOCK, SEVERE PERSONAL INJURY OR DEATH.



WARNING

THE UNIT MUST BE PERMANENTLY GROUNDED. A GROUNDING LUG IS PROVIDED. FAILURE TO GROUND THIS UNIT CAN RESULT IN FIRE OR ELEC-TRICAL SHOCK CAUSING PROPERTY DAMAGE, SEVERE PERSONAL INJURY OR DEATH.



A WARNING

ONLY ELECTRIC HEATER KITS SUPPLIED BY THIS MANUFACTURER AS DESCRIBED IN THIS PUBLICATION HAVE BEEN DESIGNED, TESTED, AND **EVALUATED BY A NATIONALLY RECOGNIZED SAFETY TESTING AGENCY** FOR USE WITH THIS UNIT. USE OF ANY OTHER MANUFACTURED ELECTRIC HEATERS INSTALLED WITHIN THIS UNIT MAY CAUSE HAZARDOUS CONDI-TIONS RESULTING IN PROPERTY DAMAGE, FIRE, BODILY INJURY OR DEATH.

WARNING

PROPOSITION 65: THIS APPLIANCE CONTAINS FIBERGLASS INSULATION. RESPIRABLE PARTICLES OF FIBERGLASS ARE KNOWN TO THE STATE OF CALIFORNIA TO CAUSE CANCER.

WARNING

THE MANUFACTURER'S WARRAN-TY DOES NOT COVER ANY DAM-AGE OR DEFECT TO THE HEAT PUMP CAUSED BY THE ATTACH-MENT OR USE OF ANY COMPO-**ACCESSORIES** NENTS. **DEVICES (OTHER THAN THOSE AUTHORIZED BY THE MANUFAC-**TURER) INTO, ONTO OR IN CON-JUNCTION WITH THE HEAT PUMP. YOU SHOULD BE AWARE THAT THE USE OF UNAUTHORIZED COM-PONENTS, ACCESSORIES OR MAY **ADVERSELY** DEVICES AFFECT THE OPERATION OF THE **HEAT PUMP AND MAY ALSO ENDANGER LIFE AND PROPERTY.** THE MANUFACTURER DISCLAIMS ANY RESPONSIBILITY FOR SUCH LOSS OR INJURY RESULTING FROM THE USE OF SUCH UNAU-THORIZED COMPONENTS, ACCES-SORIES OR DEVICES.

II. INTRODUCTION

This booklet contains the installation and operating instructions for your package heat pump. There are a few precautions that should be taken to derive maximum satisfaction from it. Improper installation can result in unsatisfactory operation or dangerous conditions.

Read this booklet and any instructions packaged with separate equipment required to make up the system prior to installation. Give this booklet to the owner and explain its provisions. The owner should retain this booklet for future reference.

NOTE: A load calculation must be performed to properly determine the required heating and cooling for the structure. Also, the duct must be properly designed and installed for proper airflow. Existiing ductwork must be inspected for proper size and sealed system. Proper airflow is necessary for both user comfort and equipment performance.

IMPORTANT: Proper application, installation and maintenance of this equipment is a must if consumers are to receive the full benefit for which they have paid.

A. R-410A REFRIGERANT

All units are factory charged with R-410A refrigerant.

1. Specification of R-410A:

Application: R-410A is not a drop-in replacement for R-22; equipment designs must accommodate its higher pressures. It cannot be retrofitted into R-22 units.

Pressure: The pressure of R-410A is approximately 60% (1.6 times) greater than R-22. Recovery and recycle equipment, pumps, hoses and the like need to have design pressure ratings appropriate for R-410A. Manifold sets need to range up to 800 psig high-side and 250 psig low-side with a 550 psig low-side retard. Hoses need to have a service pressure rating of 800 psig. Recovery cylinders need to have a 400 psig service pressure rating. DOT 4BA400 or DOT BW400.

Combustibility: At pressures above 1 atmosphere, mixture of R-410A and air can become combustible. **R-410A and air should never be mixed in tanks or supply lines, or be allowed to accumulate in storage tanks. Leak checking should never be done with a mixture of R-410A and air. Leak checking can be performed safely with nitrogen or a mixture of R-410A and nitrogen.**

- 2. Quick Reference Guide For R-410A
- R-410A refrigerant operates at approximately 60% higher pressure (1.6 times) than R-22. Ensure that servicing equipment is designed to operate with R-410A.
- R-410A refrigerant cylinders are pink.
- R-410A, as with other HFC's is only compatible with POE oils.
- Vacuum pumps will not remove moisture from POE oil.
- R-410A systems are to be charged with liquid refrigerants. Prior to March 1999, R-410A refrigerant cylinders had a dip tube. These cylinders should be kept upright for equipment charging. Post March 1999 cylinders do not have a dip tube and should be inverted to ensure liquid charging of the equipment.
- Do not install a suction line filter drier in the liquid line.
- A liquid line filter drier is standard on every unit.
- Desiccant (drying agent) must be compatible for POE oils and R-410A.
- 3. Evaporator Coil / TXV

The thermostatic expansion valve is specifically designed to operate with R-410A. **DO NOT use an R-22 TXV.** The existing evaporator must be replaced with the factory specified TXV evaporator specifically designed for R-410A.

4. Tools Required For Installing & Servicing R-410A Models

Manifold Sets:

- -Up to 800 PSIG High side
- -Up to 250 PSIG Low Side
- -550 PSIG Low Side Retard

Manifold Hoses:


-Service Pressure Rating of 800 PSIG

Recovery Cylinders:


- -400 PŚIG Pressure Rating
- -Dept. of Transportation 4BA400 or BW400

A CAUTION


R-410A systems operate at higher pressures than R-22 systems. Do not use R-22 service equipment or components on R-410A equipment.



DUCT CONNECTIONS



SQUARE DUCT CONNECTIONS



IMPORTANT: DO NOT SCREW OR DRILL OUTSIDE THE DESIGNATED AREAS.

III. CHECKING PRODUCT RECEIVED

Upon receiving the unit, inspect it for any damage from shipment. Claims for damage, either shipping or concealed, should be filed immediately with the shipping company. Check the unit model number, heating size, electrical characteristics, and accessories to determine if they are correct.

IV. EQUIPMENT PROTECTION FROM THE **ENVIRONMENT**

The metal parts of this unit may be subject to rust or deterioration in adverse environmental conditions. This oxidation could shorten the equipment's useful life. Salt spray, fog or mist in seacoast areas, sulphur or chlorine from lawn watering systems, and various chemical contaminants from industries such as paper mills and petroleum refineries are especially corrosive.

If the unit is to be installed in an area where contaminants are likely to be a problem, special attention should be given to the equipment location and exposure.

- 1. Avoid having lawn sprinkler heads spray direction on the unit cabinet.
- 2. In coastal areas, locate the unit on the side of the building away from the waterfront.
- 3. Shielding provided by a fence or shrubs may give some protection.
- 4. Elevating the unit off its slab or base enough to allow air circulation will help avoid holding water against the basepan.

Regular maintenance will reduce the buildup of contaminents and help to protect the unit's finish.



▲ WARNING

DISCONNECT ALL POWER TO THE UNIT BEFORE STARTING MAINTE-NANCE. FAILURE TO DO SO CAN RESULT IN SEVERE ELECTRICAL SHOCK OR DEATH.

- 1. Frequent washing of the cabinet, fan blade and coil with fresh water will remove most of the salt or other contaminants that build up on the unit.
- 2. Regular cleaning and waxing of the cabinet with an automobile polish will provide some protection.
- 3. A liquid cleaner may be used several times a year to remove matter that will not wash off with water.

Several different types of protective coatings are offered in some areas. These coatings may provide some benefit, but the effectiveness of such coating materials cannot be verified by the equipment manufacturer.

The best protection is frequent cleaning, maintenance and minimal exposure to contaminants.

V. INSTALLATION

A. GENERAL


1. PRE-INSTALLATION CHECK-POINTS


Before attempting any installation, the following points should be carefully considered:

- a. Structural strength of supporting members. (rooftop installation)
- b. Clearances and provision for servicing.
- c. Power supply and wiring.
- d. Air duct connections.
- e. Drain facilities and connections.
- f. Location for minimum noise.

2. LOCATION

These units are designed for outdoor installations. They can be mounted on a slab or rooftop. They are not to be installed within any part of a structure such as an attic, crawl space, closet, or any other place where condenser air flow is restricted or other than outdoor ambient conditions prevail. Since the application of the units is of the outdoor type, it is important to consult your local code authorities at the time the first installation is made.





B. OUTSIDE SLAB INSTALLATION (Typical outdoor slab installations are shown in Figure 2.)

- 1. Select a location where external water drainage cannot collect around the unit.
- Provide a level concrete slab extending 3" beyond all four sides of the unit. The slab should be sufficient above grade to prevent ground water from entering the unit.

IMPORTANT: To prevent transmission of noise or vibration, slab should not be connected to building structure.

- 3. The location of the unit should be such as to provide proper access for inspection and servicing.
- 4. Locate unit where operating sounds will not disturb owner or neighbors.
- 5. Locate unit so roof runoff water does not pour directly on the unit. Provide gutter or other shielding at roof level. Do not locate unit in an area where excessive snow drifting may occur or accumulate.
- 6. It is essential that the unit be elevated above the base pad to allow for condensate drainage and possible refreezing of condensation. Provide a base pad which is slightly pitched away from the structure. Route condensate off base pad to an area which will not become slippery and result in personal injury.

IMPORTANT: Avoid blocking openings in bottom of unit.

7. Where snowfall is anticipated, the height of the unit above the ground level must be considered. Mount unit high enough to be above average area snowfall and to allow for proper condensate drainage.

IMPORTANT: Avoid blocking openings in bottom of unit.

C. CLEARANCES

The following minimum clearances must be observed for proper unit performance and serviceability.

- Provide 30" minimum clearance at the front and 18" on the right side of the unit for service access. Provide 12" minimum clearance on the left side of the unit for air inlet.
- Provide 60" minimum clearance between top of unit and maximum 3 foot overhang.

- 3. Unit is design certified for application on combustible flooring with 0" minimum clearance.
- 4. See Figure 2 for illustration of minimum installation-service clearances.

D. ROOFTOP INSTALLATION

- 1. Before locating the unit on the roof, make sure that the strength of the roof and beams is adequate at that point to support the weight involved. (See specification sheet for weight of unit.) This is very important and user's responsibility.
- 2. The unit should be placed on a solid and level platform of adequate strength.
 - IMPORTANT: Avoid blocking openings in bottom of unit. (See Figure 3). Provision for disposal of outdoor coil defrost water runoff must be provided.
- 3. The location of the unit on the roof should be such as to provide proper access for inspection and servicing.

IMPORTANT: If unit will not be put into service immediately, cover supply and return openings to prevent excessive condensation.

DUCTWORK VI.

Ductwork should be fabricated by the installing contractor in accordance with local codes and NFPA90A. Industry manuals may be used as a guide when sizing and designing the duct system - contact Air Conditioning Contractors of America, 1513 16th St. N.W., Washington, D.C. 20036.



▲ WARNING

DO NOT, UNDER ANY CIRCUMSTANCES, CONNECT RETURN DUCTWORK TO ANY OTHER HEAT PRODUCING DEVICE SUCH AS A FIREPLACE INSERT, STOVE, ETC. UNAUTHORIZED USE OF SUCH DEVICES MAY RESULT IN FIRE, CARBON MONOXIDE POISONING, EXPLOSION, PROPERTY DAMAGE, SEVERE PERSONAL INJURY OR DEATH.

Place the unit as close to the space to be air conditioned as possible allowing clearance dimensions as indicated. Run ducts as directly as possible to supply and return outlets. Use of non-flammable waterproof flexible connectors on both supply and return connections at the unit to reduce noise transmission is recommended.

It is preferable to install the unit on the roof of the structure if the registers or diffusers are located on the wall or in the ceiling. Consider a slab installation when the registers are low on a wall or in the floor.

On ductwork exposed to outside air conditions of temperature and humidity, use a minimum of 2" of insulation and a vapor barrier. Distribution system in attic, furred space or crawl space should be insulated with at least 2" of insulation with vapor barrier. One-half to 1" thickness of insulation is usually sufficient for ductwork inside the air conditioned

Provide balancing dampers for each branch duct in the supply system. Properly support the ductwork from the structure.

When installing ductwork use noncombustible flexible connectors between ductwork and unit to reduce noise and vibration transmission into the ductwork.

VII. FILTERS

Filters are not provided with this unit. They must be supplied and installed in the return air duct by the installer. A field installed filter grille is recommended for easy and convenient access to the filters for periodic inspection and cleaning. Filters must have adequate face area for the rated air quantity of the unit. See General Database for recommended filter size.

VIII. CONDENSATE DRAIN

The indoor coil condensate drain ends with a PVC stub. A trap is provided in for proper condensate drainage and to prevent debris from being drawn into the unit. Do not connect drain to closed sewer line. It is not recommended that a PVC cement or other permanent installation be used so that the drain line and/or drain pan can be easily cleaned in the future. The drain trap is located in the control box during shipping. To install, slide clear plastic tube over drain pan connection. The white PVC trap can be oriented as required by installation.


IX. CONDENSATE DRAIN, OUTDOOR COIL

The outdoor coil during heating operation will sweat or run water off. The outdoor coil will also run water off during the defrost cycle. See Section V, Installation, for mounting precautions.

FIGURE 4
REMOVABLE CONDENSATE
DRAIN PAN AND REMOVAL
PROCEDURE

A small side panel grants access to a removable, sloped drain pan (A), which helps to ensure indoor air quality (IAQ) throughout the life of the unit. A drain trap (B) assembly is provided for convenience.





X. ELECTRICAL WIRING

Field wiring must comply with the National Electrical Code* and applicable local codes. *C.E.C. in Canada

A. POWER WIRING

- 1. It is important that proper electrical power is available at the unit. Voltage should not vary more than 10% from that stamped on the unit rating plate. On three phase units, phases must be balanced within 3%.
- 2. Install a branch circuit disconnect within sight of the unit and of adequate size to handle the starting current. (See Heater Kit Tables.)
- 3. For branch circuit wiring (main power supply to unit disconnect), the minimum wire size can be determined from the National Electrical Code or Canadian Electrical Code or nameplate or from Heater Kit Tables.
- This unit supports both single and dual point electrical connection for unit and electric heat accessory.
- 5. Power wiring must be run in grounded rain-tight conduit.

B. POWER WIRING AND ELECTRIC HEATER KIT INSTRUCTIONS

- 1. Turn off power to unit.
- 2. Remove control box access panel.
- 3. Remove unit indoor section top cover.
- 4. Remove wire notch cover from control bulkhead and discard. Retain screw.
- Remove heater element cover plate from blower outlet opening and discard. Retain screws.
- Mount heater fuse block assembly in location indicated with the three included screws.
- Route wire harness assembly through wire notch in control bulkhead and mount element assembly in blower outlet opening with screws previously retained.
- Center wire routing plate over notch in blower bulkhead and secure with screw previously retained.
- Route and tie wiring as shown in Figure 5. Wiring must not contact moving parts or uninsulated electrical connections.
- 10. Replace unit indoor top cover.
- 11. Connect power and control wiring as indicated below:
 - a. Single-point wiring: Connect high voltage field power leads to heater kit fuse block and connect included unit power pigtails from heater kit fuse block to unit



TURN OFF ELECTRIC POWER AT THE FUSE BOX OR SERVICE PANEL BEFORE MAKING ANY ELECTRICAL CONNECTIONS.

ALSO, THE GROUND CONNECTION MUST BE COMPLETED BEFORE MAKING LINE VOLTAGE CONNECTIONS. FAILURE TO DO SO CAN RESULT IN ELECTRICAL SHOCK, SEVERE PERSONAL INJURY OR DEATH.


- contactor L1 and L3 connections. Connect ground lead to ground lug on heater kit fuse block.
- b. **Dual-circuit wiring:** Remove unit power pigtails from heater kit fuse block and discard. Connect one set of high voltage field power circuit leads to the heater kit fuse block and connect ground lead to ground lug on heater kit fuse block.


 Connect the second set of high voltage field power leads to L1 and L3 on the unit
 - Connect the second set of high voltage field power leads to L1 and L3 on the unit contactor. Connect ground lead to ground lug on control box bulkhead.
- c. Connect heater kit control plug to receptacle in control box.
- 12. Replace control box access panel.
- 13. Restore power to unit and verify proper unit and heater kit operation.

C. CONTROL WIRING (Class II)

- 1. Do not run low voltage wiring in conduit with power wiring.
- 2. Control wiring is routed through the 7/8" hole corner adjacent to the control box. See Electrical Connections, Figure 1. Use a minimum #18 AWG thermostat wire. For wire lengths exceeding 50', use #16 AWG thermostat wire. The low voltage wires are connected to the unit pigtails which are supplied with the unit in the low voltage connection box located within the unit control box. See Figure 5.
- 3. It is necessary that only heat pump thermostats be used.
- Figure 6 shows representative low voltage connection diagrams. Read your thermostat installation instructions for any special requirements for your specific thermostat.

FIGURE 5
HEATER KIT INSTALLATION





NOTE — Units installed in Canada require that an outdoor thermostat (30,000 min. cycles of endurance) be installed and be wired with C.E.C. Class I wiring.

D. INTERNAL WIRING

1. A diagram of the internal wiring of this unit is located on the electrical control box cover. If any of the original wire as supplied with the appliance must be replaced, the wire gauge and insulation must be the same as original wiring.

E. GROUNDING



THE UNIT MUST BE PERMANENTLY GROUNDED. A GROUNDING LUG IS PROVIDED. FAILURE TO GROUND THIS UNIT CAN RESULT IN FIRE OR ELECTRICAL SHOCK CAUSING PROPERTY DAMAGE, SEVERE PERSONAL INJURY OR DEATH.

F. THERMOSTAT

Mount the thermostat on an inside wall about five feet above the floor in a location where it will not be affected by unconditioned air, sun, or drafts from open doors or other sources. READ installation instructions in heat pump thermostat package CAREFULLY because each has some different wiring requirements.

XI. INDOOR AIR FLOW DATA

All 208/230 volt units are equipped with multi-speed indoor blower motors. Each unit is shipped factory wired for the proper speed at a normal external static. See Airflow Performance Table for blower performance.

XII. PRE-START CHECK

- 1. Is unit properly located and level?
- Is ductwork insulated, weatherproofed, with proper spacing to combustible materials?
- 3. Is air free to travel to and from outdoor coil? (See Figure 1.)

FIGURE 6 **VOLTAGE CONNECTIONS DIAGRAM** STANDARD WITH ONE OUTDOOR THERMOSTAT W/EMERGENCY HEAT RELAY UNIT CONTROL WIRE PIGTAILS **THERMOSTAT** SUB-BASE THERMOSTAT UNIT CONTROL SUB-BASE - RED RED OUTDOOR BK/GR **(**G)-THERMOSTAT W/EMERGENCY **BROWN B**) HEAT RELAY **BROWN** $\langle X \rangle$ BROWN YELLOW Œ> BK/GR (VZ)

IF EMERGENCY HEAT RELAY AND OUTDOOR THERMOSTATS ARE NOT USED, A JUMPER BETWEEN "W2"AND "E" CAN BE INSTALLED TO TRANSFER CONTROL OF HEATING TO THE FIRST STAGE WHEN THE SYSTEM SWITCH IS IN THE

- Is the wiring correct, tight, and according to unit wiring diagram?
- 5. Is unit grounded?

EMERGENCY HEAT POSITION .

- 6. Are field supplied air filters in place and clean?
- 7. Do the outdoor fan and indoor blower turn freely without rubbing, and are they tight on the motor shafts?
- 8. Has crankcase heat been on for at least 12 hours?
- 9. Is unit elevated to allow for outdoor coil condensate drainage during heating operation and defrost?

XIII. STARTUP

- 1. Turn thermostat to "OFF," turn "on" power supply at disconnect switch.
- 2. Turn temperature setting as high as it will go.
- 3. Turn fan switch to "ON."
- 4. Indoor blower should run. Be sure it is running in the right direction.
- 5. Turn fan switch to "AUTO." Turn system switch to "COOL" and turn temperature setting below room temperature. Unit should run in cooling mode.
- 6. Is outdoor fan operating correctly in the right direction?

- 7. Is compressor running correctly.
- 8. Turn thermostat system switch to "HEAT." Unit should stop. Wait 5 minutes, then raise temperature setting to above room temperature. Unit should run in heating mode and after about 30 to 50 seconds auxiliary heaters, if installed, should come
- 9. Check the refrigerant charge using the instructions located on control box cover. Replace service port caps. Service port cores are for system access only and will leak if not tightly capped.
- 10 Turn thermostat system switch to proper mode "HEAT" or "COOL" and set thermostat to proper temperature setting. Record the following after the unit has run some time.

A. Operating Mode	
B. Discharge Pressure (High)	PSIG
C. Vapor Pressure at Compressor (Low)	
D. Vapor Line Temperature at Compressor	°F.
E. Indoor Dry Bulb	°F.
F. Indoor Wet Bulb	°F.
G. Outdoor Dry Bulb	°F.
H. Outdoor Wet Bulb	°F.
Voltage at Contactor	Volts
J. Current at Contactor	Amps
K. Model Number	
L. Serial Number	
M.Location	
N. Owner	
O. Date	

- 11. Adjust discharge air grilles and balance system.
- 12. Check ducts for condensation and air leaks.
- 13. Check unit for tubing and sheet metal rattles.
- 14. Instruct the owner on operation and maintenance.
- 15. Leave "USE AND CARE" instructions with owner.

XIV. OPERATION

Most single phase units are not equipped with start relay or start capacitor. It is important that such systems be off for a minimum of 5 minutes before restarting to allow equalization of pressures. Do not move the thermostat to cycle unit without waiting five minutes. To do so may cause the compressor to stop on an automatic open overload device or blow a fuse. Poor electrical service can cause nuisance tripping in overloads or blow fuses.

IMPORTANT: The compressor has an internal overload protector. Under some conditions, it can take up to 2 hours for this overload to reset. Make sure overload has had time to reset before condemning the compressor.

These units are equipped with a time delay control (TDC1). The control allows the blower to operate for 45 to 90 seconds after the thermostat is satisfied.

XV. AUXILIARY HEAT

The amount of auxiliary heat required depends on the heat loss of the structure to be heated and the capacity of the heat pump. It is good practice to install strip heat to maintain at least 60°F indoor temperatures in case of compressor failure. The auxiliary heat is energized by the second stage of the thermostat. The amount of electric heat that is allowed to come on, as determined by the output of the heat pump, may be controlled by an outdoor thermostat.



A WARNING

ONLY ELECTRIC HEATER KITS SUPPLIED BY THIS MANUFACTURER AS DESCRIBED IN THIS PUBLICATION HAVE BEEN DESIGNED, TESTED, AND **EVALUATED BY A NATIONALLY RECOGNIZED SAFETY TESTING AGENCY** FOR USE WITH THIS UNIT. USE OF ANY OTHER MANUFACTURED ELECTRIC HEATERS INSTALLED WITHIN THIS UNIT MAY CAUSE HAZARDOUS CONDI-TIONS RESULTING IN PROPERTY DAMAGE, FIRE, BODILY INJURY OR DEATH.

A. CONTROL SYSTEM OPERATION

1. In the cooling mode, the thermostat will, on a call for cooling, energize the compressor contactor and the indoor blower relay. The indoor blower can be operated

- continuously by setting the thermostat fan switch at the "ON" position. The reversing valve coil is de-energized when the changeover relay is energized.
- 2. In the heating mode, the first heat stage of the thermostat will energize the compressor contactor and the indoor blower relay. The second heat stage will turn on one or more supplementary resistance heaters. The reversing valve is energized except in defrost, while the changeover relay is de-energized except in defrost. If required or considered desirable, the resistance heat may also be controlled by outdoor thermostats.

XVI. DEMAND DEFROST CONTROL

The demand defrost control is a printed circuit board assembly consisting of solid state control devices with electro-mechanical outputs. The demand defrost control monitors the outdoor ambient temperature, outdoor coil temperature, and the compressor runtime to determine when a defrost cycle is required.

DEFROST INITIATION

A defrost will be initiated when the three conditions below are satisfied:

- 1) The outdoor coil temperature is below 35°F.
- The compressor has operated for at least 34 minutes with the outdoor coil temperature below 35°F.
- 3) The measured difference between the ambient temperature and the outdoor coil temperature is greater than the calculated delta T.

Additionally, a defrost will be initiated if six hours of accumulated compressor run-time has elapsed without a defrost with the outdoor coil temperature below 35°F.

DEFROST TERMINATION

Once a defrost is initiated, the defrost will continue until fourteen minutes has elapsed **or** the coil temperature has reached the terminate temperature. The terminate temperature is factory set at 70°F, although the temperature can be changed to 50°F, 60°F, 70°F or 80°F by relocating a jumper on the board.

TEMPERATURE SENSORS

The coil sensor is clipped to the top tube on the outdoor coil at the point fed by the distribution tubes from the expansion device (short 3/8" dia. tube). The air sensor is located behind the compressor access panel.

If the ambient sensor fails the defrost control will initiate a defrost every 34 minutes with the coil temperature below 35°F.

If the coil sensor fails the defrost control will not initiate a defrost.

TEST MODE

The test mode is initiated by shorting the TEST pins. In this mode of operation, the enable temperature is ignored and all timers are sped up by a factor of 240. To initiate a manual defrost, short the TEST pins. Remove the short when the system switches to defrost mode. The defrost will terminate on time (14 minutes) or when the termination temperature has been achieved. Short TEST pins again to terminate the defrost immediately.

TROUBLE SHOOTING DEMAND DEFROST

Set the indoor thermostat select switch to heat and thermostat lever to a call for heat.

Jumper the "test pins" to put the unit into defrost. If the unit goes into defrost and comes back out of defrost, the indication is that the control is working properly.

If the unit did not go into defrost using the test pins, check to ensure that 24V is being supplied to the control board. If 24V is present then replace the control.

XVII. GENERAL DATA - RQPM NOMINAL SIZES 2-5 TONS [7-17.6 kW]

Model RQPM- Series	A024JK	A030JK	A036CK	A036JK
Cooling Performance ¹				Continued ->
Gross Cooling Capacity Btu [kW]	24,000 [7.03]	29,400 [8.61]	36,000 [10.55]	36,000 [10.55]
EER/SEER ²	12/14	12.05/14	11.6/14	11.6/14
Nominal CFM/ARI Rated CFM [L/s]	800/800 [378/378]	1000/1000 [472/472]	1200/1200 [566/566]	1200/1200 [566/566]
ARI Net Cooling Capacity Btu [kW]	23,600 [6.91]	29,000 [8.5]	35,400 [10.37]	35,400 [10.37]
Net Sensible Capacity Btu [kW]	18,400 [5.39]	23,000 [6.74]	27,600 [8.09]	27,600 [8.09]
Net Latent Capacity Btu [kW]	5,200 [1.52]	6,000 [1.76]	7,800 [2.29]	7,800 [2.29]
Net System Power kW	2	2.41	3.05	3.05
Heating Performance (Heat Pumps) ³		2.71	0.00	0.00
High Temp. Btuh [kW] Rating	23,200 [6.8]	28,000 [8.2]	34,200 [10.02]	34,200 [10.02]
System Power KW / COP	1.93/3.5	2.27/3.62	2.78/3.6	2.78/3.6
Low Temp. Btuh [kW] Rating	13,200 [3.87]	15,200 [4.45]	19,000 [5.57]	19,000 [5.57]
System Power KW / COP	1.71/2.26	2.01/2.22	2.48/2.24	2.48/2.24
HSPF (Btu/Watts-hr)	8	8	8	8
Compressor	0	0	0	0
No./Type	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll
Outdoor Sound Rating (dB) ⁴	76	76	76	76
Outdoor Coil - Fin Type	Louvered	Louvered	Louvered	Louvered
Tube Type	Rifled	Rifled	Rifled	Rifled
Tube Type Tube Size in. [mm] OD	0.375 [9.5]			
		0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	10.44 [0.97]	12.65 [1.18]	12.65 [1.18]	12.65 [1.18]
Rows / FPI [FPcm]	1 / 20 [8]	1 / 20 [8]	1 / 20 [8]	1 / 20 [8]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Indoor Coil - Fin Type	Louvered Rifled	Louvered Rifled	Louvered Rifled	Louvered Rifled
Tube Type				
Tube Size in. [mm]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	4.33 [0.4]	4.33 [0.4]	4.33 [0.4]	4.33 [0.4]
Rows / FPI [FPcm]	2 / 15 [6]	3 / 13 [5]	3 / 13 [5]	3 / 13 [5]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Drain Connection No./Size in. [mm]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]
Outdoor Fan - Type	Propeller	Propeller	Propeller	Propeller
No. Used/Diameter in. [mm]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]
Drive Type/No. Speeds	Direct/1	Direct/1	Direct/1	Direct/1
CFM [L/s]	3200 [1510]	3200 [1510]	3200 [1510]	3200 [1510]
No. Motors/HP	1 at 1/3 HP			
Motor RPM	825	825	825	825
Indoor Fan - Type	FC Centrifugal	FC Centrifugal	FC Centrifugal	FC Centrifugal
No. Used/Diameter in. [mm]	1/10x9 [254x228.6]	1/10x9 [254x228.6]	1/10x9 [254x228.6]	1/10x9 [254x228.6]
Drive Type/No. Speeds	Direct/2	Direct/2	Direct/2	Direct/2
No. Motors	1	1	1	1
Motor HP	1/2	1/2	1/2	1/2
Motor RPM	1050	1050	1050	1050
Motor Frame Size	48	48	48	48
Filter - Type	Field Supplied	Field Supplied	Field Supplied	Field Supplied
Furnished	No	No	No	No
(NO.) Size Recommended in. [mm x mm x mm]	(1)1x20x16 [25x508x406]	(1)1x20x20 [25x508x508]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]
Refrigerant Charge Oz. [g]	90 [2552]	93 [2637]	93 [2637]	93 [2637]
Weights				
Net Weight lbs. [kg]	308 [140]	331 [150]	356 [161]	356 [161]
Ship Weight lbs. [kg]	332 [151]	355 [161]	380 [172]	380 [172]

- 1. Cooling Performance is rated at 95° F ambient, 80° F entering dry bulb, 67° F entering wet bulb. Gross capacity does not include the effect of fan motor heat. ARI capacity is net and includes the effect of fan motor heat. Units are suitable for operation in CFM range shown in airflow tables. Units are certified in accordance with the Unitary Air Conditioner Equipment certification program, which is based on ARI Standard 210/240 or 360.
- 2. EER and/or SEER are rated at ARI conditions and in accordance with DOE test procedures.
- 3. Heating Performance is rated at 47° F ambient, 70° F entering dry bulb for High Temp rating and 17° F ambient, 70° F entering dry bulb for Low Temp rating. Performance ratings do include the effect of fan motor heat.
- 4. Outdoor Sound Rating shown is tested in accordance with ARI Standard 270.

GENERAL DATA - RQPMNOMINAL SIZES 2-5 TONS [7-17.6 kW]

Model RQPM- Series	A042CK	A042JK	A048CK	A048JK
Cooling Performance ¹				Continued ->
Gross Cooling Capacity Btu [kW]	44,000 [12.89]	44,000 [12.89]	49,000 [14.36]	49,000 [14.36]
EER/SEER ²	11.85/14	11.85/14	11.8/14	11.8/14
Nominal CFM/ARI Rated CFM [L/s]	1400/1450 [661/684]	1400/1450 [661/684]	1600/1550 [755/731]	1600/1550 [755/731]
ARI Net Cooling Capacity Btu [kW]	43,000 [12.6]	43,000 [12.6]	48,000 [14.06]	48,000 [14.06]
Net Sensible Capacity Btu [kW]	31,800 [9.32]	31,800 [9.32]	36,800 [10.78]	36,800 [10.78]
Net Latent Capacity Btu [kW]	11,200 [3.28]	11,200 [3.28]	11,200 [3.28]	11,200 [3.28]
Net System Power kW	3.63	3.63	4.1	4.1
Heating Performance (Heat Pumps) 3	3.03	3.03	4.1	4.1
High Temp. Btuh [kW] Rating	38,500 [11.28]	38,500 [11.28]	45,000 [13.18]	45,000 [13.18]
System Power KW / COP	3.31/3.4	3.31/3.4	3.59/3.66	3.59/3.66
Low Temp. Btuh [kW] Rating	21,800 [6.39]	21,800 [6.39]	25,400 [7.44]	25,400 [7.44]
System Power KW / COP	3/2.06	3/2.06	3.22/2.3	3.22/2.3
•	8	8	3.2212.3 8	3.2212.3 8
HSPF (Btu/Watts-hr)	0	0	0	0
Compressor	4/0	4/0	4/0	4/0
No./Type	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll
Outdoor Sound Rating (dB) ⁴	78	78	78	78
Outdoor Coil - Fin Type	Louvered	Louvered	Louvered	Louvered
Tube Type	Rifled	Rifled	Rifled	Rifled
Tube Size in. [mm] OD	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	16.54 [1.54]	16.54 [1.54]	16.54 [1.54]	16.54 [1.54]
Rows / FPI [FPcm]	1 / 22 [9]	1 / 22 [9]	1 / 22 [9]	1 / 22 [9]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Indoor Coil - Fin Type	Louvered	Louvered	Louvered	Louvered
Tube Type	Rifled	Rifled	Rifled	Rifled
Tube Size in. [mm]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	5.78 [0.54]	5.78 [0.54]	5.78 [0.54]	5.78 [0.54]
Rows / FPI [FPcm]	3 / 13 [5]	3 / 13 [5]	3 / 13 [5]	3 / 13 [5]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Drain Connection No./Size in. [mm]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]
Outdoor Fan - Type	Propeller	Propeller	Propeller	Propeller
No. Used/Diameter in. [mm]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]
Drive Type/No. Speeds	Direct/1	Direct/1	Direct/1	Direct/1
CFM [L/s]	4200 [1982]	4200 [1982]	4200 [1982]	4200 [1982]
No. Motors/HP	1 at 1/3 HP			
Motor RPM	1075	1075	1075	1075
Indoor Fan - Type	FC Centrifugal	FC Centrifugal	FC Centrifugal	FC Centrifugal
No. Used/Diameter in. [mm]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]
Drive Type/No. Speeds	Direct/2	Direct/2	Direct/2	Direct/2
No. Motors	1	1	1	1
Motor HP	3/4	3/4	3/4	3/4
Motor RPM	1050	1050	1050	1050
Motor Frame Size	48	48	48	48
Filter - Type	Field Supplied	Field Supplied	Field Supplied	Field Supplied
Furnished	No	No	No	No
(NO.) Size Recommended in. [mm x mm x mm]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]
Refrigerant Charge Oz. [g]	128 [3629]	128 [3629]	120 [3402]	120 [3402]
Weights				· ·
Net Weight lbs. [kg]	408 [185]	408 [185]	429 [195]	429 [195]
Ship Weight lbs. [kg]	434 [197]	434 [197]	455 [206]	455 [206]
1 0 [1.0]	r 1	r 1	r 1	r 1

- 1. Cooling Performance is rated at 95° F ambient, 80° F entering dry bulb, 67° F entering wet bulb. Gross capacity does not include the effect of fan motor heat. ARI capacity is net and includes the effect of fan motor heat. Units are suitable for operation in CFM range shown in airflow tables. Units are certified in accordance with the Unitary Air Conditioner Equipment certification program, which is based on ARI Standard 210/240 or 360.
- 2. EER and/or SEER are rated at ARI conditions and in accordance with DOE test procedures.
- 3. Heating Performance is rated at 47° F ambient, 70° F entering dry bulb for High Temp rating and 17° F ambient, 70° F entering dry bulb for Low Temp rating. Performance ratings do include the effect of fan motor heat.
- 4. Outdoor Sound Rating shown is tested in accordance with ARI Standard 270.

GENERAL DATA - RQPMNOMINAL SIZES 2-5 TONS [7-17.6 kW]

Model RQPM- Series	A060CK	A060JK
Cooling Performance ¹		
Gross Cooling Capacity Btu [kW]	61,000 [17.87]	61,000 [17.87]
EER/SEER ²	11.9/14	11.9/14
Nominal CFM/ARI Rated CFM [L/s]	2000/1900 [944/897]	2000/1900 [944/897]
ARI Net Cooling Capacity Btu [kW]	59,500 [17.43]	59,500 [17.43]
Net Sensible Capacity Btu [kW]	45,300 [13. 2 7]	45,300 [13. 2 7]
Net Latent Capacity Btu [kW]	14,200 [4.16]	14,200 [4.16]
Net System Power kW	5	5
Heating Performance (Heat Pumps) ³		
High Temp. Btuh [kW] Rating	59,500 [17.43]	59,500 [17.43]
System Power KW / COP	4.74/3.7 2	4.74/3.72
Low Temp. Btuh [kW] Rating	36,600 [10.7 2]	36,600 [10.7 2]
System Power KW / COP	4.26/2.54	4.26/2.54
HSPF (Btu/Watts-hr)	8	8
Compressor		
No./Type	1/Copeland Scroll	1/Copeland Scroll
Outdoor Sound Rating (dB) ⁴	78	78
Outdoor Coil - Fin Type	Louvered	Louvered
Tube Type	Rifled	Rifled
Tube Size in. [mm] OD	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	16.54 [1.54]	16.54 [1.54]
Rows / FPI [FPcm]	2 / 18 [7]	2 / 18 [7]
Refrigerant Control	TX Valves	TX Valves
Indoor Coil - Fin Type	Louvered	Louvered
Tube Type	Rifled	Rifled
Tube Size in. [mm]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	5.78 [0.54]	5.78 [0.54]
Rows / FPI [FPcm]	4 / 13 [5]	4 / 13 [5]
Refrigerant Control	TX Valves	TX Valves
Drain Connection No./Size in. [mm]	1/1 [25.4]	1/1 [25.4]
Outdoor Fan - Type	Propeller	Propeller
No. Used/Diameter in. [mm]	1/ 24 [609.6]	1/24 [609.6]
• •	Direct/1	Direct/1
Drive Type/No. Speeds CFM [L/s]	4000 [1888]	4000 [1888]
No. Motors/HP	1 at 1/3 HP	1 at 1/3 HP
Motor RPM	1075	1075
Indoor Fan - Type	FC Centrifugal	FC Centrifugal
No. Used/Diameter in. [mm]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]
Drive Type/No. Speeds	Direct/2	Direct/2
No. Motors	1	1
Motor HP	1	1
Motor RPM	1050	1050
Motor Frame Size	48	
Filter - Type	Field Supplied	48 Field Supplied
Furnished	No	No
(NO.) Size Recommended in. [mm x mm x mm]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610] 193 [5472]
Refrigerant Charge Oz. [g] Weights	193 [547 2]	190 [34/2]
•	404 [3 40]	404 [240]
Net Weight lbs. [kg]	481 [2 18]	481 [2 18]
Ship Weight lbs. [kg]	507 [2 30]	507 [2 30]

- 1. Cooling Performance is rated at 95° F ambient, 80° F entering dry bulb, 67° F entering wet bulb. Gross capacity does not include the effect of fan motor heat. ARI capacity is net and includes the effect of fan motor heat. Units are suitable for operation in CFM range shown in airflow tables. Units are certified in accordance with the Unitary Air Conditioner Equipment certification program, which is based on ARI Standard 210/240 or 360.
- 2. EER and/or SEER are rated at ARI conditions and in accordance with DOE test procedures.
- 3. Heating Performance is rated at 47° F ambient, 70° F entering dry bulb for High Temp rating and 17° F ambient, 70° F entering dry bulb for Low Temp rating. Performance ratings do include the effect of fan motor heat.
- 4. Outdoor Sound Rating shown is tested in accordance with ARI Standard 270.

GENERAL DATA - RQNMNOMINAL SIZES 2-5 TONS [7-17.6 kW]

Model RQNM- Series	A024JK	A030JK	A036CK	A036JK
Cooling Performance ¹				Continued ->
Gross Cooling Capacity Btu [kW]	24,600 [7.21]	29,800 [8.73]	36,600 [10.72]	36,600 [10.72]
EER/SEER ²	11/13	11.15/13	11/13	11/13
Nominal CFM/ARI Rated CFM [L/s]	800/800 [378/378]	1000/1000 [472/472]	1200/1200 [566/566]	1200/1200 [566/566]
ARI Net Cooling Capacity Btu [kW]	23,600 [6.91]	28,800 [8.44]	35,200 [10.31]	35,200 [10.31]
Net Sensible Capacity Btu [kW]	18,200 [5.33]	22,400 [6.56]	27,000 [7.91]	27,000 [7.91]
Net Latent Capacity Btu [kW]	5,400 [1.58]	6,400 [1.88]	8,200 [2.4]	8,200 [2.4]
Net System Power kW	2.14	2.58	3.2	3.2
Heating Performance (Heat Pumps) ³	2.17	2.00	0.2	0.2
High Temp. Btuh [kW] Rating	23,400 [6.86]	28,800 [8.44]	35,000 [10.26]	35,000 [10.26]
System Power KW / COP	2.07/3.34	2.45/3.44	2.95/3.48	2.95/3.48
Low Temp. Btuh [kW] Rating	13,800 [4.04]	16,200 [4.75]	19,200 [5.63]	19,200 [5.63]
System Power KW / COP	1.91/2.12	2.22/2.14	2.65/2.1	2.65/2.1
HSPF (Btu/Watts-hr)	7.7	7.7	7.7	7.7
Compressor	1.1	1.1	1.1	1.1
No./Type	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll
Outdoor Sound Rating (dB) ⁴	76	76	76	76
Outdoor Coil - Fin Type	Louvered Rifled	Louvered Rifled	Louvered Rifled	Louvered Rifled
Tube Type Tube Size in. [mm] OD	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	10.44 [0.97]	12.65 [1.18]	12.65 [1.18]	12.65 [1.18]
Rows / FPI [FPcm]	1 / 20 [8]	1 / 20 [8]	1 / 20 [8]	1 / 20 [8]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Indoor Coil - Fin Type	Louvered	Louvered	Louvered	Louvered
Tube Type	Rifled	Rifled	Rifled	Rifled
Tube Size in. [mm]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	4.33 [0.4]	4.33 [0.4]	4.33 [0.4]	4.33 [0.4]
Rows / FPI [FPcm]	2 / 15 [5]	3 / 13 [6]	3 / 13 [5]	3 / 13 [5]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Drain Connection No./Size in. [mm]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]
Outdoor Fan - Type	Propeller	Propeller	Propeller	Propeller
No. Used/Diameter in. [mm]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]
Drive Type/No. Speeds	Direct/1	Direct/1	Direct/1	Direct/1
CFM [L/s]	3200 [1510]	3200 [1510]	3200 [1510]	3200 [1510]
No. Motors/HP	1 at 1/3 HP			
Motor RPM	825	825	825	825
Indoor Fan - Type	FC Centrifugal	FC Centrifugal	FC Centrifugal	FC Centrifugal
No. Used/Diameter in. [mm]	1/10x9 [254x228.6]	1/10x9 [254x228.6]	1/10x9 [254x228.6]	1/10x9 [254x228.6]
Drive Type/No. Speeds	Direct/2	Direct/2	Direct/2	Direct/2
No. Motors	1	1	1	1
Motor HP	1/4	1/3	1/2	1/2
Motor RPM	1033	1080	1050	1050
Motor Frame Size	48	48	48	48
Filter - Type	Field Supplied	Field Supplied	Field Supplied	Field Supplied
Furnished	No	No	No	No
(NO.) Size Recommended in. [mm x mm x mm]	(1)1x20x16 [25x508x406]	(1)1x20x20 [25x508x508]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]
Refrigerant Charge Oz. [g]	90 [2552]	93 [2637]	93 [2637]	93 [2637]
Weights				
Net Weight lbs. [kg]	308 [140]	331 [150]	356 [161]	356 [161]
Ship Weight lbs. [kg]	332 [151]	355 [161]	380 [172]	380 [172]

- 1. Cooling Performance is rated at 95° F ambient, 80° F entering dry bulb, 67° F entering wet bulb. Gross capacity does not include the effect of fan motor heat. ARI capacity is net and includes the effect of fan motor heat. Units are suitable for operation in CFM range shown in airflow tables. Units are certified in accordance with the Unitary Air Conditioner Equipment certification program, which is based on ARI Standard 210/240 or 360.
- 2. EER and/or SEER are rated at ARI conditions and in accordance with DOE test procedures.
- 3. Heating Performance is rated at 47° F ambient, 70° F entering dry bulb for High Temp rating and 17° F ambient, 70° F entering dry bulb for Low Temp rating. Performance ratings do include the effect of fan motor heat.
- 4. Outdoor Sound Rating shown is tested in accordance with ARI Standard 270.

GENERAL DATA - RQNMNOMINAL SIZES 2-5 TONS [7-17.6 kW]

Model RQNM- Series	A042CK	A042JK	A048CK	A048JK
Cooling Performance ¹				Continued ->
Gross Cooling Capacity Btu [kW]	43,500 [12.75]	43,500 [12.75]	49,500 [14.5]	49,500 [14.5]
EER/SEER ²	11/13	11/13	11/13	11/13
Nominal CFM/ARI Rated CFM [L/s]	1400/1450 [661/684]	1400/1450 [661/684]	1600/1550 [755/731]	1600/1550 [755/731]
ARI Net Cooling Capacity Btu [kW]	42,000 [12.31]	42,000 [12.31]	47,500 [13.92]	47,500 [13.92]
Net Sensible Capacity Btu [kW]	30,000 [8.79]	30,000 [8.79]	35,900 [10.52]	35,900 [10.52]
Net Latent Capacity Btu [kW]	12,000 [3.52]	12,000 [3.52]	11,600 [3.4]	11,600 [3.4]
Net System Power kW	3.82	3.82	4.32	4.32
Heating Performance (Heat Pumps) ³	3.02	3.02	4.02	4.02
High Temp. Btuh [kW] Rating	39,500 [11.57]	39,500 [11.57]	46,000 [13.48]	46,000 [13.48]
System Power KW / COP	3.56/3.24	3.56/3.24	3.92/3.44	3.92/3.44
Low Temp. Btuh [kW] Rating	22,800 [6.68]	22,800 [6.68]	25,600 [7.5]	25,600 [7.5]
System Power KW / COP	3.25/2.06	3.25/2.06	3.56/2.14	3.56/2.14
HSPF (Btu/Watts-hr)	7.7	7.7	7.7	7.7
Compressor	1.1	1.1	1.1	1.1
No./Type	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll	1/Copeland Scroll
		78		
Outdoor Sound Rating (dB) ⁴	78		78	78
Outdoor Coil - Fin Type	Louvered	Louvered	Louvered	Louvered
Tube Type	Rifled	Rifled	Rifled	Rifled
Tube Size in. [mm] OD	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	16.54 [1.54]	16.54 [1.54]	16.54 [1.54]	16.54 [1.54]
Rows / FPI [FPcm]	1 / 22 [9]	1 / 22 [9]	1 / 22 [9]	1 / 22 [9]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Indoor Coil - Fin Type	Louvered	Louvered	Louvered	Louvered
Tube Type	Rifled	Rifled	Rifled	Rifled
Tube Size in. [mm]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	5.78 [0.54]	5.78 [0.54]	5.78 [0.54]	5.78 [0.54]
Rows / FPI [FPcm]	3 / 13 [5]	3 / 13 [5]	3 / 13 [5]	3 / 13 [5]
Refrigerant Control	TX Valves	TX Valves	TX Valves	TX Valves
Drain Connection No./Size in. [mm]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]	1/1 [25.4]
Outdoor Fan - Type	Propeller	Propeller	Propeller	Propeller
No. Used/Diameter in. [mm]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]	1/24 [609.6]
Drive Type/No. Speeds	Direct/1	Direct/1	Direct/1	Direct/1
CFM [L/s]	4200 [1982]	4200 [1982]	4200 [1982]	4200 [1982]
No. Motors/HP	1 at 1/3 HP			
Motor RPM	1075	1075	1075	1075
Indoor Fan - Type	FC Centrifugal	FC Centrifugal	FC Centrifugal	FC Centrifugal
No. Used/Diameter in. [mm]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]
Drive Type/No. Speeds	Direct/2	Direct/2	Direct/2	Direct/2
No. Motors	1	1	1	1
Motor HP	1/2	1/2	3/4	3/4
Motor RPM	1075	1075	1075	1075
Motor Frame Size	48	48	48	48
Filter - Type	Field Supplied	Field Supplied	Field Supplied	Field Supplied
Furnished	No	No	No	No
(NO.) Size Recommended in. [mm x mm x mm]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]
Refrigerant Charge Oz. [g]	128 [3629]	128 [3629]	120 [3402]	120 [3402]
Weights				
weights				
Net Weight lbs. [kg]	408 [185]	408 [185]	429 [195]	429 [195]

- 1. Cooling Performance is rated at 95° F ambient, 80° F entering dry bulb, 67° F entering wet bulb. Gross capacity does not include the effect of fan motor heat. ARI capacity is net and includes the effect of fan motor heat. Units are suitable for operation in CFM range shown in airflow tables. Units are certified in accordance with the Unitary Air Conditioner Equipment certification program, which is based on ARI Standard 210/240 or 360.
- 2. EER and/or SEER are rated at ARI conditions and in accordance with DOE test procedures.
- 3. Heating Performance is rated at 47° F ambient, 70° F entering dry bulb for High Temp rating and 17° F ambient, 70° F entering dry bulb for Low Temp rating. Performance ratings do include the effect of fan motor heat.
- 4. Outdoor Sound Rating shown is tested in accordance with ARI Standard 270.

GENERAL DATA - RQNMNOMINAL SIZES 2-5 TONS [7-17.6 kW]

Model RQNM- Series	A060CK	A060JK
Cooling Performance ¹		
Gross Cooling Capacity Btu [kW]	62,000 [18.17]	62,000 [18.17]
EER/SEER ²	11/13	11/13
Nominal CFM/ARI Rated CFM [L/s]	2000/1900 [944/897]	2000/1900 [944/897]
ARI Net Cooling Capacity Btu [kW]	59,000 [17.29]	59,000 [17.29]
Net Sensible Capacity Btu [kW]	44,500 [13.04]	44,500 [13.04]
Net Latent Capacity Btu [kW]	14,500 [4.25]	14,500 [4.25]
Net System Power kW	5.36	5.36
Heating Performance (Heat Pumps) ³	0.00	0.00
High Temp. Btuh [kW] Rating	61,000 [17.87]	61,000 [17.87]
System Power KW / COP	5.15/3.52	5.15/3.52
·		
Low Temp. Btuh [kW] Rating	34,400 [10.08]	34,400 [10.08]
System Power KW / COP	4.64/2.18	4.64/2.18
HSPF (Btu/Watts-hr)	7.7	7.7
Compressor	1/Canaland C	1/Canaland C!!
No./Type	1/Copeland Scroll	1/Copeland Scroll
Outdoor Sound Rating (dB) ⁴	78	78
Outdoor Coil - Fin Type	Louvered	Louvered
Tube Type	Rifled	Rifled
Tube Size in. [mm] OD	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	16.54 [1.54]	16.54 [1.54]
Rows / FPI [FPcm]	2 / 18 [7]	2 / 18 [7]
Refrigerant Control	TX Valves	TX Valves
Indoor Coil - Fin Type	Louvered	Louvered
Tube Type	Rifled	Rifled
Tube Size in. [mm]	0.375 [9.5]	0.375 [9.5]
Face Area sq. ft. [sq. m]	5.78 [0.54]	5.78 [0.54]
Rows / FPI [FPcm]	4 / 13 [5]	4 / 13 [5]
Refrigerant Control	TX Valves	TX Valves
Drain Connection No./Size in. [mm]	1/1 [25.4]	1/1 [25.4]
Outdoor Fan - Type	Propeller	Propeller
No. Used/Diameter in. [mm]	1/24 [609.6]	1/24 [609.6]
Drive Type/No. Speeds	Direct/1	Direct/1
CFM [L/s]	4000 [1888]	4000 [1888]
No. Motors/HP	1 at 1/3 HP	1 at 1/3 HP
Motor RPM	1075	1075
Indoor Fan - Type	FC Centrifugal	FC Centrifugal
No. Used/Diameter in. [mm]	1/11x9 [279.4x228.6]	1/11x9 [279.4x228.6]
Drive Type/No. Speeds	Direct/2	Direct/2
No. Motors	1	1
Motor HP	3/4	3/4
Motor RPM	1075	1075
Motor Frame Size	48	48
Filter - Type	Field Supplied	Field Supplied
Furnished	No	No
(NO.) Size Recommended in. [mm x mm x mm]	(1)1x24x24 [25x610x610]	(1)1x24x24 [25x610x610]
Refrigerant Charge Oz. [g]	193 [5472]	193 [5472]
Weights	100 [07/2]	100 [07/2]
Net Weight lbs. [kg]	481 [218]	481 [218]
Ship Weight lbs. [kg]	507 [230]	507 [230]
omp worght ibs. [kg]	007 [200]	007 [200]

- 1. Cooling Performance is rated at 95° F ambient, 80° F entering dry bulb, 67° F entering wet bulb. Gross capacity does not include the effect of fan motor heat. ARI capacity is net and includes the effect of fan motor heat. Units are suitable for operation in CFM range shown in airflow tables. Units are certified in accordance with the Unitary Air Conditioner Equipment certification program, which is based on ARI Standard 210/240 or 360.
- 2. EER and/or SEER are rated at ARI conditions and in accordance with DOE test procedures.
- 3. Heating Performance is rated at 47° F ambient, 70° F entering dry bulb for High Temp rating and 17° F ambient, 70° F entering dry bulb for Low Temp rating. Performance ratings do include the effect of fan motor heat.
- 4. Outdoor Sound Rating shown is tested in accordance with ARI Standard 270.

XVIII. MISCELLANEOUS

ELECTRICAL AND PHYSICAL DATA

			EL	ECTRICAL	DATA - RQ	PM SERIE	S				
		-A024JK	-A030JK	-A036CK	-A036JK	-A042CK	-A042JK	-A048CK	-A048JK	-A060CK	-A060JK
	Unit Operating Voltage Range	187-253	187-253	187-253	187-253	187-253	187-253	187-253	187-253	187-253	187-253
Unit Information	Minimum Circuit Ampacity	23/23	21/21	19/19	27/27	26/26	36/36	26/26	36/36	32/32	43/43
nit Info	Minimum Overcurrent Protection Device Size	30/30	30/30	25/25	35/35	30/30	45/45	30/30	45/45	40/40	50/50
ō	Maximum Overcurrent Protection Device Size	35/35	35/35	25/25	40/40	35/35	50/50	35/35	50/50	45/45	60/60
	No.	1	1	1	1	1	1	1	1	1	1
	Volts	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230
Motor	Phase	1	1	3	1	3	1	3	1	3	1
Compressor Motor	HP	2	2.5	3	3	3.5	3.5	4	4	4.5	4.5
Comp	RPM	3450	3450	3450	3450	3450	3450	3450	3450	3450	3450
	Amps (RLA)	13.5/13.5	14.1/14.1	10.4/10.4	16.7/16.7	14.1/14.1	21.8/21.8	13.7/13.7	21.8/21.8	17.9/17.9	26.4/26.4
	Amps (LRA)	58.3/58.3	73/73	88/88	79/79	95/95	112/112	110/110	117/117	120/120	150/150
	No.	1	1	1	1	1	1	1	1	1	1
for	Volts	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230
ser Mo	Phase	1	1	1	1	1	1	1	1	1	1
Condenser Motor	HP	1/3	1/3	1/3	1/3	1/3	1/3	1/3	1/3	1/3	1/3
ပိ	Amps (FLA)	1.5	1.5	1.5	1.5	1.9	1.9	1.9	1.9	1.9	1.9
	Amps (LRA)	3	3	3	3	4	4	4	4	4	4
	No.	1	1	1	1	1	1	1	1	1	1
<u> </u>	Volts	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230
Evaporator Fan	Phase	1	1	1	1	1	1	1	1	1	1
vapora	HP	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4	1	1
Ú	Amps (FLA)	4.1	4.1	4.1	4.1	6	6	6	6	7.6	7.6

ELECTRICAL AND PHYSICAL DATA

			EL	ECTRICAL	DATA - RQ	NM SERIE	S				
		-A024JK	-A030JK	-A036CK	-A036JK	-A042CK	-A042JK	-A048CK	-A048JK	-A060CK	-A060JK
L C	Unit Operating Voltage Range	187-253	187-253	187-253	187-253	187-253	187-253	187-253	187-253	187-253	187-253
Unit Information	Minimum Circuit Ampacity	20/20	21/21	17/17	25/25	23/23	33/33	23/23	33/33	31/31	41/41
nit Info	Minimum Overcurrent Protection Device Size	25/25	25/25	20/20	30/30	30/30	40/40	30/30	40/40	35/35	50/50
<u> </u>	Maximum Overcurrent Protection Device Size	30/30	35/35	25/25	40/40	35/35	50/50	35/35	50/50	45/45	60/60
	No.	1	1	1	1	1	1	1	1	1	1
_	Volts	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230
Compressor Motor	Phase	1	1	3	1	3	1	3	1	3	1
ressol	HP	2	2.5	3	3	3.5	3.5	4	4	4.5	4.5
Comp	RPM	3450	3450	3450	3450	3450	3450	3450	3450	3450	3450
	Amps (RLA)	13.5/13.5	14.1/14.1	10.4/10.4	16.7/16.7	14.1/14.1	21.8/21.8	13.7/13.7	21.8/21.8	17.9/17.9	26.4/26.4
	Amps (LRA)	58.3/58.3	73/73	88/88	79/79	95/95	112/112	83.1/83.1	117/117	120/120	150/150
	No.	1	1	1	1	1	1	1	1	1	1
otor	Volts	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230
ser Mc	Phase	1	1	1	1	1	1	1	1	1	1
Condenser Motor	HP	1/3	1/3	1/3	1/3	1/3	1/3	1/3	1/3	1/3	1/3
ŏ	Amps (FLA)	1.5	1.5	1.5	1.5	1.9	1.9	1.9	1.9	1.9	1.9
	Amps (LRA)	3	3	3	3	4	4	4	4	4	4
	No.	1	1	1	1	1	1	1	1	1	1
u e	Volts	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230	208/230
Evaporator Fan	Phase	1	1	1	1	1	1	1	1	1	1
vapor	HP	1/4	1/3	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4
	Amps (FLA)	1.5	1.7	2.5	2.5	2.7	2.7	3.2	3.2	5.8	5.8
	Amps (LRA)	2.6	2.6	5	5	4.6	4.6	4.4	4.4	11.3	11.3

INDOOR AIRFLOW PERFORMANCE FOR 2-5 TON PACKAGE HEAT PUMPS – 230V RQPM SERIES

																			_			_																
		1.00				732	1091	237	626	1076	209	922	1118	294	893	1114	291	1098	1151	358	1076	951	340	1331	981	454	1287	970	426	1534	994	550	1618	1055	621	1884	1077	804
		06.0	447	1043	152	788	1038	231	289	1034	199	971	1077	289	941	1077	286	1144	1114	366	1128	913	326	1376	951	440	1333	934	410	1577	296	237	1659	1014	009	1922	1045	784
		08.0	208	1001	149	845	686	220	747	686	195	1020	1035	279	066	1036	277	1190	1031	348	1180	928	313	1422	917	426	1379	895	392	1620	932	217	1700	626	582	1960	1013	764
30 Volts	s W.C.	0.70	220	915	136	901	946	210	807	942	185	1069	942	256	1038	686	265	1235	981	334	1231	849	304	1467	879	409	1425	863	380	1663	899	501	1741	943	562	1999	983	745
CFM Air Delivery/RPM/Watts-230 Volts	External Static Pressure-Inches W.C	09.0	631	860	126	826	880	196	898	893	174	1119	894	247	1086	803	246	1281	5021	322	1283	800	285	1513	833	386	1471	826	363	1706	865	484	1782	606	543	2037	952	724
ery/RPM	c Pressu	0.50	693	809	121	1014	815	182	928	809	159	1168	843	234	1135	857	233	1327	890	307	1335	758		1558	797	371	1517	787	347	1749	816	458	1823	871			919	203
ir Delive	rnal Stati	0.40	754	744	110	1071	761	173	988	756	151	1217	784	218		807	220	1373	841	292	1386	714		1604	749	350		743		1792	922	439	1864	832	499		882	089
CFM A	Exte	0.30	816	655	26	1127 1	869	159	1049	693	138	1266 1		204	1231 1	752		1418 1	792	277	1438 1	662		1649 1	502	331		969			738	416	1905 1	792	477		851	829
		0.20 0	877	601 (116	1184 1	634 (145	1109 10	619 (130	1316 12		190	1280 12		191	1464 14	743	261	1490	617 (311				1878 18	902	400	1945 19	. 692				989
				282 6						9 609	144					648 6	178		207	248 2		9 869		١		295 3					678 7	385 4				2		
		0.10	6	35	131	1240	209	161	1169)9	1,	1365	631	17.	1328	79	11	1510)/	77	1542	26	77	1740	9	56	1701	9	28	1921	<u> 1</u> 9	38	1986	731	4	2229	32	6,
			CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts
	Motor	Speed	,,,,,	-			- E		<u> </u>	<u> </u>						V T P P P P P P P P P P P P P P P P P P			- F		,,,,	<u> </u>		Į.		=	, , ,	_	l		- F		3	-		Į.		
Air- Blower Size/	Motor HP #	of Speeds		10x9	1/4	2 Speed	(X-13 Motor)	10x9 1/3 2 Speed (X-13 Motor) 10x9		10x9	1/2	2 Speed	(X-13 Motor)			11x9	1/2	2 Speed	(X-13 Motor)			11x9	3/4	2 Speed	(X-13 Motor)			11x9	3/4	2 Speed	(X-13 Motor)							
Manufacturer Recommended Air-	Flow Range	(Min / Max) CFM			0007002	006 / 00 /	875 / 1125					1005 / 1575	000					1400 / 1800						1750 / 2250	000													
	Motor Speed	From Factory			(C 40 L) (NO	Low (1 ap 2)					(C de T) wo l	Low (1 ap 2)					(C 40 F)	Low (1 ap 2)					(C de T) wo l	LOW (- ap 2)					(C ar T) wo I	Low (1 ap 2)					(C deT) WO	LOW (- ap 2)		
Nominal Cooling	Capacity	Tons			c	0.7					о Л	N.					c	o.0					у Т)					4.0) ;					ע)		

INDOOR AIRFLOW PERFORMANCE FOR 2-5 TON PACKAGE HEAT PUMPS – 208V RQPM SERIES

Nominal		Manufacturer Recommended Air	Air Blower Size/	_				S	/ Air Del	CFM Air Deliverv/RPM/Watts-208 Volts	MWatts	-208 Volt	<u>y.</u>		
Capacity	Motor Speed	Flow Range	Motor HP #	Motor					xternal St	External Static Pressure-Inches W.	sure-Inch	nes W.C.	}		
Tons	From Factory	Ξ	of Speeds	Speed		0.10	0.20	0.30	0.40	0.50	09.0	0.70	0.80	06.0	1.00
				700	CFM	626	892	825	758	169	624	222	491		
			10x9	(Tan 2)	RPM	582	909	622	723	808	851	906	966		
C	(C acT) wo	000/002	1/4	(1 ap 4)	Watts	132	110	96	106	119	123	132	144		
N O	Low (1 ap 2)		2 Speed	Ţ	CFM	1229	1170	1112	1054	966	938	879	821	292	202
			(X-13 Motor)	- Eg - F	RPM	209	634	869	761	815	880	946	686	1038	1091
				(ab)	Watts	161	145	159	173	182	196	210	220	231	237
				À	CFM	1162	1099	1035	972	806	844	781	717	654	290
			10x9	(Tan 2)	RPM	603	626	069	752	815	906	941	984	1027	1096
ر ب	(C de T) WO	875 / 1105	1/3	(1 ap 4)	Watts	143	124	136	148	157	175	180	188	192	202
	Low (1 ap 2)	0 0 0	2 Speed	Ţ	CFM	1306	1253	1200	1147	1095	1042	686	937	884	831
			(X-13 Motor)	Tan 1)	RPM	632	629	733	787	841	883	941	1035	1067	1099
				(ומהו)	Watts	174	187	201	215	227	235	248	266	273	277
				7	CFM	1328	1276	1223	1171	1118	1066	1013	961		
			10x9	(Tan 2)	RPM	642	693	747	803	852	803	988	1031		
~	(C acT) WO	1050 / 1350	1/2	(1 ap 2)	Watts	173	187	200	214	226	238	254	263		
5	Low (1 ap 4)		2 Speed	Ţ	CFM	1508	1459	1409	1359	1310	1260	1210	1160	1111	1061
			(X-13 Motor)	- 19:- F	RPM	869	738	789	839	888	933	983	1035	1103	1137
				(Watts	243	255	271	285	299	310	322	332	343	343
				7	CFM	1531	1477	1423	1370	1316	1262	1208	1154	1101	1047
			11x9	-	RPM	602	619	899	715	757	801	844	878	918	954
7	(C de T) WO	1005 / 1575	1/2	(1 ap 4)	Watts	238	227	236	251	266	281	296	307	320	333
5	Low (1 ap 4)	0.00	2 Speed	Ī	CFM	1724	1678	1632	1586	1540	1495	1449	1403	1357	1311
			(X-13 Motor)	(Tab 1)	RPM	629	671	715	759	794	834	875	911	948	977
				(db)	Watts	295	309	330	348	363	380	397	414	429	440
				700	CFM	1708	1658	1609	1559	1510	1460	1410	1361	1311	1262
			11x9	-	RPM	619	651	989	741	783	822	829	894	937	971
V	(C de T) WO	1400 / 1800	3/4	(2 dp 1)	Watts	280	284	298	323	339	322	370	385	402	415
) F	Low (1 ap 4)		2 Speed	Ī	CFM	1917	1872	1827	1782	1736	1691	1646	1601	1556	1510
			(X-13 Motor)	- B	RPM	673	702	736	269	818	860	868	928	096	686
				(ap)	Watts	377	392	409	426	451	473	490	504	518	531
				70	CFM	1954	1914	1874	1833	1793	1753	1713	1673	1632	1592
			11x9	-	RPM	719	747	779	818	857	894	928	963	866	1038
ני	l ow (Tan 2)	1750 / 2250	3/4	(1 dp	Watts	439	451	469	491	512	534	553	573	290	611
))	(1 ds -)		2 Speed	I Fig	CFM	2173	2136	2098	2061	2024	1986	1949	1911	1874	1837
			(X-13 Motor)	(Tan 1)	RPM	775	803	830	860	896	928	959	988	1019	1050
				(- Jb -)	Watts	604	622	642	663	989	206	727	745	765	784

INDOOR AIRFLOW PERFORMANCE FOR 2-5 TON PACKAGE HEAT PUMPS – 230V RQNM SERIES

		0				4	2	စ		<u> </u>								<u>ග</u>	ω	7	7	ပ	2	7	2	2	_	4	2	0	က	0	7	ω	ဖ	2	4	9
		1.00				504	1092	259										928	1108	513	52	1076	292	1387	975	62	1129.	927	465	1500	973	652	153	988	726	2015	1044	1146
		06.0				969	1072	279	423	1050	210	845	1035	329	641	1041	300	1228	1091	546	849	1035	335	1491	940	929	1214	915	483	1590	936	693	1623	951	755	2127	1025	1192
		08'0	435	982	198	874	1001	341	296	1019	227	1003	1012	349	788	1008	310	1458	1049	626	1030	898	423	1585	910	989	1293	874	503	1671	912	669	1702	924	782	2230	1009	1228
30 Volts	s W.C.	0.70	531	932	216	1020	926	357	735	934	271	1117	933	401	915	982	323	1629	1028	829	1140	831	437	1669	877	712	1365	832	522	1744	298	730	1773	889	799	2323	966	1274
I/Watts-2	ure-Inche	09.0	614	894	227	1125	877	416	843	863	280	1196	883	421	1023	968	361	1753	666	702	1208	9//	453	1742	846	729	1432	789	532	1808	833	749	1836	855	817	2408	975	1312
/ery/RPM	tic Pressi	0.50	684	266	244	1187	819	431	923	262	303	1246	824	433	1110	854	370	1841	972	734	1258	724	459	1806	808	750	1492	753	544	1863	807	753	1892	822	831	2483	926	1340
CFM Air Delivery/RPM/Watts-230 Volts	External Static Pressure-Inches W.C	0.40	740	742	254	1211	767	448	6/6	746	314	1276	292	454	1177	802	391	1905	946	762	1302	989	470	1859	780	759	1547	708	549	1909	781	760	1941	798	849	2549	938	1368
CFP	EX	0.30	782	979	269	1216	703	455	1014	629	326	1292	712	466	1225	754	387	1957	917	784	1348	633	477	1903	750	276	1595	899	226	1947	752	784	1983	756	865	2606	915	1399
		0.20	811	533	273	1223	643	468	1030	220	331	1301	646	473	1253	202	395	2008	883	908	1394	629	479	1936	727	782	1638	618	563	1976	722	787	2017	723	870	2654	897	1427
		0.10	827	450	278	1230	2/2	479	1032	533	336	1312	269	482	1261	648	398	2068	820	826	1431	240	482	1960	703	783	1674	929	275	1996	089	799	2044	689	988	2693	876	1438
		l	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts	CFM	RPM	Watts
	ō	eq		꿈	Š	ᆼ			ᆼ		Š	ᆼ			ᆼ		Ň	占		Š	ᆼ		×	ᆼ		Ñ			Ň	S			S		Ň	<u>당</u>		
	[£] Motor			Low			High			Low			High			Low			High			Low			High			Γow			High	1	11x9 Low 3/4 2 Speed (PSC Motor) High					
Blower Size/	Motor HP #	of Speeds		10x9	1/4	2 Speed	(PSC Motor)			10x9	1/3	2 Speed	(PSC Motor)			10x9	1/2	2 Speed	(PSC Motor)			11x9	1/2	2 Speed	(PSC Motor)			11x9	3/4	2 Speed	(PSC Motor)					2 Speed	2 Speea (PSC Motor)	
Manufacturer Recommended Air-	Φ	Σ			200 / 000						875 / 1125						1050 / 1350						1225 / 1575						1400 / 1800						1750 / 2250			
	Motor Speed	From Factory			Low						Low						Low						Low						Low						Low			
Nominal Cooling	Capacity	Tons			2.0						2.5						3.0						3.5						4.0						5.0			

INDOOR AIRFLOW PERFORMANCE FOR 2-5 TON PACKAGE HEAT PUMPS – 208V RQNM SERIES

ELECTRIC HEATER KIT – 1 PHASE RQNM

Š	208-240 VOLT, SINGLE PHASE, 60 HZ, AUXILLARY ELECTRIC HEATER KITS CHARACTERISTICS AND APPLICATION Single Power Supply For Both Unit And Heater Kit	С НЕАТЕР	KITS CHA	RACTERISTI Separate	CS AND A	FERISTICS AND APPLICATION Separate Power Supply For Both Unit And Heater Kit	۱ it And Hea	ter Kit
U.	Heater Heater Unit Min. Ckt		Over Current Protective Device Size	Heater Kit	Heater Kit	Heat Pump Min. Ckt.	Heat Pump Over Current Protective	Heat Pump Over Current Protective
240 V	208-240 V 240 V 208-240 V		Min/Max @ Min/Max @ 208 V 240 V	Ampacity	Size	Ampacity 208 ₇ 240	Min/Max @ Min/Max 208 V 240 V	Min/Max @ 240 V
	20/20	25/30	25/30	•		20/20	25/30	25/30
1 3.6/4.8 12.2	12.28/16.38 17.33/20 42/45	45/50	45/50	22/25	25/25	-	-	1
Ħ	26/30	09/09	09/09	33/38	35/40	-		1
1 7.2/9.6 24.5	24.57/32.76 34.7/40 64/70	0//0/	70/70	44/50	45/50	, <u>5</u>	- 10	- 0
1 36/48 12.28	- 21/21 - 28/16.38 17.33/20 43/46	45/50	50/50	22/25	25/25	-	-	
	26/30	09/09	09/09	33/38	35/40			
1 7.2/9.6 24.57	34.7/40	70/70	80/80	44/50	45/50			1
	36.85/49.13 52/60 86/96	06/06	100/100	65/75	70/80	-	-	-
	-	30/40	30/40	-	-	25/25	30/40	30/40
1 3.6/4.8 12.28/16.38	6.38 17.33/20 47/50	20/20	09/09	22/25	25/25		-	,
1 5.4/7.2 18.42/24.56	26/30	09/09	70/70	33/38	35/40		-	,
	34.7/40	70/70	80/80	44/50	45/50	•	-	1
	52/60			65/75	70/80	-	-	-
2 14.4/19.2 49.12/65.52	5.52 69.33/80 112/125	1	125/125	87/100	90/100		-	-
		40/20	40/50		-	33/33	40/50	40/50
	1	02/09	60/70	22/25	25/25			-
	26/30	70/70	70/80	33/38	35/40			
7.2/9.6	34.7/40	80/80	+	44/50	45/50			
2 10.8/14.4 36.85	36.85/49.13 52/60 98/108 46.12/65.52 66.33/80 112/133	100/100	110/110	65//5	/0/80			
t	-	╁	1		-	33/33	40/50	40/20
1 3.6/4.8 12.2	12.28/16.38 17.33/20 55/58	02/09	02/09	22/25	25/25			
	26/30	20/80	70/80	33/38	35/40	-	-	1
	34.7/40	80/80		44/50	45/50	-		1
2 10.8/14.4 36.8	36.85/49.13 52/60 98/108	100/100	110/110	65/75	70/80	-	-	
2 14.4/19.2 49.1	49.12/65.52 69.33/80 120/133	125/125	150/150	87/100	90/100	-		1
-	41/41	20/09	20/60	-	-	41/41	20/60	20/60
	3/16.38 17.33/20	80/80	80/80	22/25	25/25	-	-	-
	18.42/24.56 26/30 74/79	06/06		33/38	35/40	-	-	1
7.2/9.6	76/30		_	44/50	45/50	<u>'</u>		
10.8/14.4	34.7/40		125/125	65/75	70/80		,	-
2 14.4/19.2 49.12/65.52	34.7/40 52/60 1	110/110	1					

ELECTRIC HEATER KIT – 3 PHASE RQNM


	• •	208-240 \	OLT, TH	208-240 VOLT, THREE PHASE, 60		XILLARY I	ELECTRIC P	IEATER K	ITS CHAR	ACTERISTI	CS AND AI	HZ, AUXILLARY ELECTRIC HEATER KITS CHARACTERISTICS AND APPLICATION	_	
			Single P	Single Power Supply For Bo	or Both Unit ≠	oth Unit And Heater Kit	(i t			Separate	Power Supp	Separate Power Supply For Both Unit And Heater Kit	nit And Heat	er Kit
Model	RXQJ-	JO V	No. of	Rated Heater	Heater	Heater	Unit Min. Ckt	Over Current Protective Device Size	urrent Jovice Size	Heater Kit	Heater Kit	Heat Pump	Heat Pump Over Current Protective	np Over rotective
Š.	Heater Kit	Tomonte	Sequence	⋧		Ā	Ampacity @	ו וסופכווגפ ד	Sevice Oike	Min. Ckt.	Max. Fuse	Ampacity 208	Device Size	Size
RONM-	Nominal kW		Steps	240 V	208-240 V	240 V	208-240 V	Min/Max @ Min/Max @	Min/Max @	Ampacity	Size	Olipacity 200	Min/Max @	1√Max @ Min/Max @
								208 V	240 V			240	208 V	240 V
	No Heat			-	•	-	17/17	20/25	20/25			17/17	20/25	20/25
A036C	C10C	2	1	7.2/9.6	24.57/32.76	20/23.1	42/46	45/45	20/20	25/29	25/30	-		-
	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	55/61	09/09	70/70	38/44	40/45			-
	No Heat			-		-	23/23	30/35	30/35			23/23	30/35	30/32
7070	C10C	2	1	7.2/9.6	24.57/32.76	20/23.1	48/52	09/09	09/09	25/29	25/30			
704	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	99/19	02/02	70/70	38/44	40/45		•	
	C20C	4	2	14.4/19.2	49.12/65.52	40/46.3	73/81	08/08	06/06	20/28	20/60	-	-	-
	No Heat		-	-	-	-	23/23	30/35	30/32	-	-	23/23	30/35	30/32
7870	C10C	2	1	7.2/9.6	24.57/32.76	20/23.1	48/52	09/09	09/09	25/29	25/30	-	-	-
200	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	99/09	09/09	70/70	38/44	40/45	-	-	-
	C20C	4	2	14.4/19.2	49.12/65.52	40/46.3	73/81	80/80	06/06	20/28	20/60	1	-	-
	No Heat			-	-	-	31/31	35/45	35/45	-	-	31/31	35/45	35/45
00900	C10C	2	1	7.2/9.6	24.57/32.76	20/23.1	26/59	09/09	02/09	25/29	25/30			
	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	69/74	02/02	80/80	38/44	40/45	-	-	-
	C20C	4	2	14.4/19.2	49.12/65.52	40/46.3	81/88	06/06	06/06	20/28	20/60			


ELECTRIC HEATER KIT – 1 PHASE RQPM


		208-240 V	OLT, SIN	208-240 VOLT, SINGLE PHASE, 60 HZ, AUXILLARY ELECTRIC HEATER KITS CHARACTERISTICS AND APPLICATION	Ξ, 60 HZ, AL	IXILLARY	ELECTRIC	HEATER K	(ITS CHA	RACTERIST	ICS AND A	PPLICATION	Z	
			Single Po	Single Power Supply For Botl	or Both Unit,	h Unit And Heater Kit	3			Separate	Power Supp	Separate Power Supply For Both Unit And Heater Kit	nit And Hea	ter Kit
Model No.	RXQJ- Heater Kit	No. of	No. of Sequence		Heater KBTU/Hr @	Heater Amp. @ 208			Over Current Protective Device Size	Heater Kit Min. Ckt.	Heater Kit Max. Fuse	Heat Pump Min. Ckt.	Heat Pu Current F Devio	Heat Pump Over Current Protective Device Size
RQPM-	Nominal kW	Elements	Steps	240 V	208-240 V		208-240 V	Min/Max @ Min/Max 208 V 240 V	Min/Max @ 240 V	Ampacity	Size	Ampacity 208 240	Min/Max @ 208 V	Min/Max @ Min/Max @ 208 V 240 V
	No Heat			-	1	,	23/23	30/32	30/35	-	-	23/23	30/35	30/35
A0241	C05J	1	1	3.6/4.8	12.28/16.38	17.33/20	45/48	45/50	20/20	22/25	25/25	1	-	1
200	C07J	_	1	5.4/7.2	18.42/24.56	26/30	25/60	09/09	09/09	33/38	35/40	1		
	C10J	2	1	7.2/9.6	24.57/32.76	34.7/40	66/73	70/70	80/80	44/50	45/50	-		-
	No Heat	-	-	-	-	-	24/24	30/32	30/32	-	-	24/24	30/35	30/35
	C05J	1	1	3.6/4.8	12.28/16.38	17.33/20	45/49	45/50	20/20	22/25	25/25		-	
A030J	C07J	1	1	5.4/7.2	18.42/24.56		56/61	09/09	70/70	33/38	35/40	1	-	•
	C10J	2	1	7.2/9.6	24.57/32.76	()	67/74	70/70	80/80	44/50	45/50		-	•
	C15J	3	2	10.8/14.4	36.85/49.13	52/60	89/99	06/06	100/100	65/75	70/80		-	•
	No Heat	-	-	-	-	-	27/27	35/40	35/40	-	-	27/27	35/40	35/40
	C05J	1	1	3.6/4.8	12.28/16.38	17.33/20	49/52	20/60	09/09	22/25	25/25	-	-	
40361	C07J	1	1	5.4/7.2	18.42/24.56	26/30	59/64	09/09	70/70	33/38	35/40	•	-	•
300	C10J	2	1	7.2/9.6	24.57/32.76	34.7/40	70/77	70/70	80/80	44/50	45/50	-	-	-
	C15J	3	2	10.8/14.4	36.85/49.13	52/60	92/102	100/100	110/110	65/75	08/02	•	-	•
	C20J	4	2	14.4/19.2	49.12/65.52	69.33/80	114/127	125/125	150/150	87/100	90/100	•	-	•
	No Heat	1	-	-	-	-	98/98	45/50	45/50	-	-	98/98	45/50	45/50
	C05J	_	1	3.6/4.8	12.28/16.38	1	47/61	02/09	70/70	22/25	25/25	1		
A042.1	C07J	-	_	5.4/7.2	18.42/24.56		68/73	70/80	80/80	33/38	35/40	•	-	•
27	C10J	2	1	7.2/9.6	24.57/32.76	34.7/40	79/86	80/90	06/06	44/50	45/50	•	-	•
	C15J	3	2	10.8/14.4	36.85/49.13	52/60	101/111	110/110	125/125	65/75	70/80	•	-	-
	C20J	4	2	14.4/19.2	49.12/65.52	69.33/80	112/136	125/125	150/150	87/100	90/100	1		•
	No Heat	-	-	-	1	-	98/98	45/50	45/50	-	-	98/98	45/50	45/50
	C05J	_	1	3.6/4.8	12.28/16.38	1	57/61	02/09	70/70	22/25	25/25	-	-	-
A048.1	C07J	-	1	5.4/7.2	18.42/24.56		68/73	70/80	80/80	33/38	35/40		-	
3	C10J	2	_	7.2/9.6	24.57/32.76	(,)	79/86	80/90	06/06	44/50	45/50	•	-	•
	C15J	3	2	10.8/14.4	36.85/49.13	52/60	101/111	110/110	125/125	65/75	70/80	•	-	•
	C20J	4	2	14.4/19.2	49.12/65.52	69.33/80	122/136	125/125	150/150	87/100	90/100	•		
	No Heat	-	-	-	-	-	43/43	20/09	20/60	-	-	43/43	20/60	20/60
	C05J	-	_	3.6/4.8	12.28/16.38	7	65/68	80/80	80/80	22/25	25/25	•	-	•
A060.1	C07J	-	-	5.4/7.2	18.42/24.56		75/80	06/06	06/06	33/38	35/40		-	•
2	C10J	2	1	7.2/9.6	24.57/32.76	Ĭ	86/93	90/100	100/100	44/50	45/50			-
	C15J	3	2	10.8/14.4	36.85/49.13		108/118	110/110	125/125	65/75	70/80		-	-
	C20J	4	2	14.4/19.2	49.12/65.52	69.33/80	130/143	150/150	150/150	87/100	90/100	-	-	


ELECTRIC HEATER KIT – 3 PHASE RQPM


		208-240 V	OLT, THI	208-240 VOLT, THREE PHASE, 60 H	, 60 HZ, AU	XILLARY I	Z, AUXILLARY ELECTRIC HEATER KITS CHARACTERISTICS AND APPLICATION	IEATER KI	TS CHAR	ACTERISTI	CS AND AF	PLICATION		
			Single P	Single Power Supply For Both	or Both Unit	ո Unit And Heater Kit	Çit			Separate	Power Supp	Separate Power Supply For Both Unit And Heater Kit	it And Heat	er Kit
Model No.	RXQJ- Heater Kit	No. of	No. of Sequence	No. of Rated Heater Sequence KW @ 208-	Heater KBTU/Hr @	Heater Amp. @ 208	Unit Min. Ckt Ampacity @	Over Current Protective Device Size	urrent evice Size	Heater Kit Min. Ckt.	Heater Kit Max. Fuse	Heat Pump Min. Ckt.	Heat Pump Over Current Protective Device Size	np Over otective Size
RQPM-	RQPM- Nominal kW	Elements	Steps	240 V	208-240 V	240 V		Min/Max @ Min/Max @ 208 V 240 V	Min/Max @ 240 V	Ampacity	Size	Ampacity 208 240	Min/Max @ Min/Max @ 208 V 240 V	//Jin/Max @ 240 V
	No Heat			•	•		19/19	25/25	25/25			19/19	25/25	25/25
A036C	C10C	2	_	7.2/9.6	24.57/32.76	20/23.1	44/48	45/45	20/20	25/29	25/30			
	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	57/61	09/09	70/70	38/44	40/45	-	-	-
	No Heat						26/26	30/35	30/32			26/26	30/35	30/35
000	C10C	2	1	7.2/9.6	24.57/32.76	20/23.1	51/55	09/09	09/09	25/29	25/30			
70470	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	64/69	02/02	20/20	38/44	40/45			
	C20C	7	2	14.4/19.2	49.12/65.52	40/46.3	76/84	08/08	06/06	20/28	20/60	-	-	-
	No Heat			-	•		26/26	30/32	30/32			26/26	30/35	30/35
0,000	C10C	2	_	7.2/9.6	24.57/32.76	20/23.1	51/54	09/09	09/09	25/29	25/30			
70400	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	69/29	02/02	20/20	38/44	40/45			
	C20C	4	2	14.4/19.2	49.12/65.52	40/46.3	28/92	08/08	06/06	20/28	20/60	-	-	-
	No Heat		•	-	-	-	32/32	40/45	40/45	-	-	32/32	40/45	40/45
70800	C10C	2	1	7.2/9.6	24.57/32.76	20/23.1	57/61	09/09	20/20	25/29	25/30			
	C15C	3	2	10.8/14.4	36.85/49.13	30.1/34.7	92/69	02/02	80/80	38/44	40/45	-	-	•
	C20C	4	2	14.4/19.2	49.12/65.52	40/46.3	82/90	06/06	06/06	20/28	20/60			












INSTRUCTIONS:

- 1. CONNECT PRESSURE GAUGES TO SUCTION AND DISCHARGE PORTS ON UNIT.
- 2. MEASURE AIR TEMPERATURE TO: (a) OUTDOOR COIL FOR COOLING, (b) INDOOR COIL FOR HEATING.
- 3. PLACE AN "X" ON THE APPROPRIATE CHART WHERE THE SUCTION AND DISCHARGE PRESSURES CROSS.
- 4. IF "X" IS BELOW AMBIENT TEMPERATURE LINE, ADD CHARGE AND REPEAT STEP 3.


92-1022/3-01-0

5. IF "X" IS ABOVE AMBIENT TEMPERATURE LINE, RECOVER EXCESS CHARGE AND REPEAT STEP 3.



INSTRUCTIONS:


- 1. CONNECT PRESSURE GAUGES TO SUCTION AND DISCHARGE PORTS ON UNIT.
- 2. MEASURE AIR TEMPERATURE TO: (a) OUTDOOR COIL FOR COOLING, (b) INDOOR COIL FOR HEATING.
- 3. PLACE AN "X" ON THE APPROPRIATE CHART WHERE THE SUCTION AND DISCHARGE PRESSURES CROSS.
- 4. IF "X" IS BELOW AMBIENT TEMPERATURE LINE, ADD CHARGE AND REPEAT STEP 3.
- 5. IF "X" IS ABOVE AMBIENT TEMPERATURE LINE, RECOVER EXCESS CHARGE AND REPEAT STEP 3. 92-102273-02-00



CAUTION: BEFORE FINAL REFRIGERANT CHECK, INDOOR RETURN AIR TEMPERATURE MUST BE BETWEEN 72°F & 76°F DB AT 50% R.H. (HEATING AND COOLING), AND NO ICE ON OUTDOOR COILS (HEATING).


INSTRUCTIONS:

- 1. CONNECT PRESSURE GAUGES TO SUCTION AND DISCHARGE PORTS ON UNIT.
- 2. MEASURE AIR TEMPERATURE TO: (a) OUTDOOR COIL FOR COOLING, (b) INDOOR COIL FOR HEATING.
- 3. PLACE AN "X" ON THE APPROPRIATE CHART WHERE THE SUCTION AND DISCHARGE PRESSURES CROSS.
- 4. IF "X" IS BELOW AMBIENT TEMPERATURE LINE, ADD CHARGE AND REPEAT STEP 3.
- 5. IF "X" IS ABOVE AMBIENT TEMPERATURE LINE, RECOVER EXCESS CHARGE AND REPEAT STEP 3. 92-102273-03-00




INSTRUCTIONS:

- 1. CONNECT PRESSURE GAUGES TO SUCTION AND DISCHARGE PORTS ON UNIT.
- 2. MEASURE AIR TEMPERATURE TO: (a) OUTDOOR COIL FOR COOLING, (b) INDOOR COIL FOR HEATING.
- 3. PLACE AN "X" ON THE APPROPRIATE CHART WHERE THE SUCTION AND DISCHARGE PRESSURES CROSS.
- 4. IF "X" IS BELOW AMBIENT TEMPERATURE LINE, ADD CHARGE AND REPEAT STEP 3.
- 5. IF "X" IS ABOVE AMBIENT TEMPERATURE LINE, RECOVER EXCESS CHARGE AND REPEAT STEP 3. 92-102273-04-00



INSTRUCTIONS:

- 1. CONNECT PRESSURE GAUGES TO SUCTION AND DISCHARGE PORTS ON UNIT.
- 2. MEASURE AIR TEMPERATURE TO: (a) OUTDOOR COIL FOR COOLING, (b) INDOOR COIL FOR HEATING.
- 3. PLACE AN "X" ON THE APPROPRIATE CHART WHERE THE SUCTION AND DISCHARGE PRESSURES CROSS.
- 4. IF "X" IS BELOW AMBIENT TEMPERATURE LINE, ADD CHARGE AND REPEAT STEP 3.
- 5. IF "X" IS ABOVE AMBIENT TEMPERATURE LINE, RECOVER EXCESS CHARGE AND REPEAT STEP 3. 92-102273-05-00



- 1. CONNECT PRESSURE GAUGES TO SUCTION AND DISCHARGE PORTS ON UNIT.
- 2. MEASURE AIR TEMPERATURE TO: (a) OUTDOOR COIL FOR COOLING, (b) INDOOR COIL FOR HEATING.
- 3. PLACE AN "X" ON THE APPROPRIATE CHART WHERE THE SUCTION AND DISCHARGE PRESSURES CROSS.
- 4. IF "X" IS BELOW AMBIENT TEMPERATURE LINE, ADD CHARGE AND REPEAT STEP 3.
- 5. IF "X" IS ABOVE AMBIENT TEMPERATURE LINE, RECOVER EXCESS CHARGE AND REPEAT STEP 3. 92-102273-06-00

40 CM 0306