



TECHNICAL SERVICE DEPARTMENT
Technical Service Bulletin
1-800-432-8373



TRD Replacement Site Inspection Report

Issue	Yes	No
1. Is there any gasoline stored in the same room as the water heater?		
2. Are there any other flammable vapor substances stored in the same room as the water heater? (These may include paint thinner, turpentine, or other petroleum based product.)		
3. Are the pre-filter holes at the bottom of the water heater clean and free of accumulated dust and dirt?		
4. Are there any boxes, bags, clothes or other obstructions within 3 feet of the pre-filter holes at the bottom of the water heater? (These obstructions can prevent proper fresh air flow to the water heater.)		
5. Does the water heater appear to have enough fresh combustion air to sustain main burner? (If installed in a closet, then the heater must have a secondary fresh air source such as louvered doors, etc.)		