

DIVISION 23 52 33.13**WATER-TUBE BOILERS****PART 1 - GENERAL****1.1 SUMMARY**

- A. Section includes condensing gas-fired, copper finned-tube hydronic heating boilers

Specifier Note: Use as needed

B. Related Sections

1. Building Services Piping – Division 23 21 00
2. Breeching, Chimneys, and Stacks (Venting) – Division 23 51 00
3. HVAC Instrumentation and Controls – Division 23 09 00
4. Electrical – Division 23 09 33

1.2 REFERENCES

- A. ANSI Z21.13/CSA 4.9
- B. ASHRAE 90.1
- C. ASME Boiler and Pressure Vessel Code, Sections IV and VIII
- D. UMC, Section 1107.6
- E. ANSI/ASHRAE 15-1994, Section 8.13.6
- F. National Fuel Gas Code, ANSI Z223.1/NFPA 54
- G. BTS - 2000
- H. National Electric Code, ANSI/NFPA 70
- I. ASME CSD-1 (when required)

1.3 SUBMITTALS

- A. Product data sheet (including dimensions, rated capacities, shipping weights, accessories)
- B. Wiring diagram
- C. Warranty information
- D. Installation and operating instructions

1.4 QUALITY ASSURANCE

- A. Regulatory Requirements
 1. ANSI Z21.13/CSA 4.9
 2. Local and national air quality regulations for low NOx (0-30 PPM NOx emissions) boilers
- B. Certifications
 1. CSA - ANSI Z21.13/CSA 4.9
 2. ASME H Stamp and National Board Listed – Primary Heat Exchanger
 3. ASME U Stamp and National Board Listed – Secondary Stainless Steel Condensing Heat Exchanger
 4. CSA Certified – AB1953 & VLA 193 Low Lead Compliant
 5. CEC

1.5 WARRANTY

- A. Limited one-year warranty from date of installation - parts
- B. Limited twenty-five-year thermal shock warranty – heat exchangers
- C. Limited five-year open-system warranty (copper) from date of installation, ten-year (cupro-nickel)
- D. Limited ten-year closed-system heat exchanger warranty (copper and cupro-nickel)

- E. Limited ten-year secondary stainless steel condensing heat exchanger warranty

PART 2 - PRODUCTS

2.1 MANUFACTURER

A. Raypak, Inc.

1. Contact: 2151 Eastman Ave., Oxnard, CA 93030; Telephone: (805) 278-5300; Fax: (800) 872-9725; Web site: www.raypak.com
2. Product: XTherm™ condensing water-tube hydronic boiler(s)

2.2 BOILERS

A. General

1. The boiler(s) shall be fired with _____ gas at a rated input of _____ BTU/hr.
2. The boiler(s) shall be CSA tested and certified with a minimum thermal efficiency of 96 percent at full fire (up to 99% at part load).
3. The boiler(s) shall be ASME inspected and stamped and National Board registered for 160 PSIG maximum allowable working pressure and 250°F maximum allowable temperature, complete with a Manufacturer's Data Report.
4. The boiler(s) shall have a floor loading of 70 lbs. /square foot or less.
5. The boiler(s) shall be capable of operating with inlet water temperatures as low as 50°F.

B. Primary Heat Exchanger

1. The primary heat exchanger shall be of a single-bank, vertical multi-pass design and shall completely enclose the combustion chamber for maximum efficiency. The tubes shall be set vertically and shall be rolled into a powder-coated, ASME boiler quality, carbon steel tube sheet.
2. The primary heat exchanger shall be sealed to 160 PSIG rated low lead bronze headers with silicone "O" rings.
3. The low water volume primary heat exchanger shall be explosion-proof on the water side and shall carry a twenty-five-year warranty against thermal shock.
4. The headers shall be secured to the tube sheet by stud bolts with flange nuts to permit inspection and maintenance without removal of external piping connections. A heavy gauge stainless steel slotted heat exchanger wrap shall ensure proper combustion gas flow across the copper-finned tubes.
5. The flue connection, combustion air opening, gas connection, water connections, electrical connections and condensate drain shall be located on the rear.
6. The primary heat exchanger shall have accessible boiler drain valves with hose bibs to drain the water section of the primary heat exchanger.

C. Condensing Secondary Heat Exchanger

1. The condensing secondary heat exchanger shall be a single-bank, multi-pass design constructed of stainless steel and bear the ASME U stamp.
2. The secondary heat exchanger shall have accessible boiler drain valves with hose bibs to drain the water section of the heat exchanger.

D. Condensate Drain

1. The boiler(s) will feature a condensate drain switch which will shut down the boiler(s) if the condensate drain is blocked.

E. Burners

1. The combustion chamber shall be of the sealed-combustion type employing the Raypak high-temperature radially-fired knit burner, mounted in a vertical orientation.
2. The burner must be capable of firing at both a complete blue flame with maximum gas and air input as well as firing infrared when gas and air are reduced. The burner must be capable of firing at 100% of rated input when supplied with 4.0" WC of inlet gas pressure, so as to maintain service under heavy demand conditions; no exceptions.

3. The burner shall use a combustion air blower to precisely control the fuel/air mixture for maximum efficiency throughout the entire range of modulation. The combustion air blower shall operate for a pre-purge period before burner ignition and a post-purge period after burner operation to clear the combustion chamber.
 4. The blower shall infinitely vary its output in response to a Pulse Width Modulation (PWM) signal, supplied directly from the VERSA IC® modulating temperature controller, thereby electronically and precisely adjusting the volume of air and gas supplied for combustion. Minimum fire shall be as low as 9.0 percent of rated input (natural gas or propane gas).
- F. Ignition Control System
1. The boiler(s) shall be equipped with a 100 percent safety shutdown.
 2. The ignition shall be Hot Surface Ignition (HSI) type with full flame rectification by remote sensing separate from the ignition source, with a three-try-for-ignition sequence, to ensure consistent operation.
 3. The igniter will be located to the side of the heat exchanger to protect the device from condensation during start-up.
 4. The ignition control module shall include an LED that indicates fifteen (15) individual diagnostic flash codes and transmits any fault codes to the display.
 5. An external viewing port shall be provided, permitting visual observation of burner operation.
- G. Gas Train
1. The boiler(s) shall have a firing/leak test valve and pressure test valve as required by CSD-1.
 2. The boiler(s) shall have dual-seated main gas valve.
 3. Gas control trains shall have a redundant safety shut-off feature, main gas regulation, shut-off cock and plugged pressure tapping to meet the requirements of ANSI Z21.13/CSA 4.9.
 4. High gas pressure safety switch
- H. Boiler Control
1. The following safety controls shall be provided:
 - a. High limit control with manual reset
 - b. Flow switch, mounted and wired
 - c. _____ PSIG ASME pressure relief valve, piped by the installer to an approved drain
 - d. Temperature and pressure gauge (shipped loose)
 2. The boiler(s) shall be equipped with the VERSA IC modulating temperature controller with 7-inch touch screen display that incorporates an adjustable energy-saving pump control relay and freeze protection and is factory mounted and wired to improve system efficiency; six water sensors included (system sensor is shipped loose).
- I. Firing Mode: Provide electronic modulating control of the gas input to the boiler.
- J. Boiler Diagnostics
1. Provide external LED panel displaying the following boiler status/faults:
 - a. Power on – Green
 - b. Call for heat – Amber
 - c. Burner firing – Blue
 - d. Service – Red
 2. Provide monitoring of all safeties, internal/external interlocks with fault display by a 7-inch Touch Screen display:
 - a. System status
 - b. Ignition failure
 - c. Condensate blockage
 - d. Blower speed error
 - e. Low 24 VAC
 - f. Manual reset high limit
 - g. Auto reset high limit
 - h. Blocked vent
 - i. High gas pressure switch
 - j. Controller alarm
 - k. Flow switch
 - l. Sensor failure

1. Inlet sensor (open or short)
 2. Outlet sensor (open or short)
 3. System sensor (open or short)
 4. Air sensor (open or short)
 5. Indirect DHW sensor (open or short)
 6. Indirect DHW tank sensor (open or short)
 7. Cold water protection sensor (open or short)
- m. Factory option
- n. Internal control fault
- o. ID card fault
- p. Cascade communications error

Specifier Note: The remaining items in this section are options. Delete those that are not being specified.

- q. Auto reset high limit (optional)
 - r. Low water cut-off (optional)
 - s. Low gas pressure switch (optional)
3. Provide ignition module indicating the following flash codes by LED signal and displayed on the 7-inch Touch Screen display:
- a. 1 flash – low air pressure
 - b. 2 flashes – flame in the combustion chamber w/o CFH
 - c. 3 flashes – ignition lock-out (flame failure)
 - d. 4 flashes – low hot surface igniter current
 - e. 5 flashes – low 24VAC
 - f. 6 flashes – vent temperature
 - g. 7 flashes – hi-limit
 - h. 8 flashes – sensor fault
 - i. 9 flashes – low gas pressure
 - j. 10 flashes – water pressure
 - k. 11 flashes – blower speed fault
 - l. 12 flashes – low water cut-off
 - m. 13 flashes – hi-temperature ΔT
 - n. 14 flashes – FT-BUS communications
 - o. 15 flashes – general safety limit
- K. Combustion Chamber: The combustion chamber wrapper shall be insulated to reduce standby radiation losses, reducing jacket losses and increasing unit efficiency.
- L. Cabinet
1. The corrosion-resistant galvanized-steel jackets shall be finished with a baked-on epoxy powder coat, which is suitable for outdoor installation, applied prior to assembly for complete coverage, and shall incorporate louvers in the outer panels to divert air past heated surfaces.
 2. The boiler(s), if located on a combustible floor, shall not require a separate combustible floor base.
 3. The boiler(s) shall connect both the combustion air and flue products through the back of the unit.
 4. The boiler shall have as standard an internal, combustion air filter rated to MERV 8 (>95% arrestance).
- M. Boiler Pump – The boiler(s) shall be equipped with a factory-packaged pump system.
- N. Cold Water Protection System
1. The boiler(s) shall be configured with an automatic cold water protection proportional bypass system that ensures the boiler primary heat exchanger will experience inlet temperatures in excess of 120°F in less than 7 minutes to avoid damaging condensation.
 2. The cold water protection system shall be configured with a variable-flow injection system that is controlled by the VERSA IC control system that diverts the correct amount of heated outlet water directly into the boiler loop to maintain the required minimum inlet temperature. The VERSA IC control temperature sensor shall be located in the inlet header of the boiler.

2.3 BOILER OPERATING CONTROLS

- A. The boiler(s) shall feature an integrated VERSA IC modulating digital controller, mounted and wired.
- B. The system sensor shall be shipped loose for field installation by installing contractor. Inlet/Outlet sensors are factory-installed.
- C. The control shall have the ability to provide cascade control of up to 4 boilers as a single system via 2-wire communication.
- D. Each boiler shall have the ability to receive a 0 to 10 VDC signal from the Central Energy Management and Direct Digital Control System (EMCS) to vary the setpoint control or firing rate. Each boiler shall have an alarm contact for connection to the central EMCS system.
- E. Each boiler shall be equipped with Modbus communications compatibility with up to 146 points of data available.

Specifier Note: The remaining items in this section are options. Delete those that are not being specified.

- a. B-85 Gateway – BACnet MS/TP, BACnet IP, N2 Metasys or Modbus TCP (optional)
- b. B-86 Gateway – LonWorks (optional)

2.4 DIRECT VENT

- A. The boilers(s) shall meet safety standards for direct vent equipment as noted by the Uniform Mechanical Code, section 1107.6, and ASHRAE 15-1994, section 8.13.6.
- B. Boiler shall be capable of combined combustion air duct and vent lengths not to exceed 200 equivalent feet.

2.5 SOURCE QUALITY CONTROL

- A. The boiler(s) shall be completely assembled, wired, and fire-tested prior to shipment from the factory.
- B. The boiler(s) shall be furnished with the sales order, ASME Manufacturer's Data Report(s), inspection sheet, wiring diagram, rating plate and Installation and Operating Manual.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Must comply with:
 - 1. Local, state, provincial, and national codes, laws, regulations and ordinances
 - 2. National Fuel Gas Code, ANSI Z223.1/NFPA 54 – latest edition
 - 3. National Electrical Code, ANSI/NFPA 70 – latest edition
 - 4. Standard for Controls and Safety Devices for Automatically Fired Boilers, ANSI/ASME CSD-1, when required
 - 5. Canada only: CAN/CGA B149 Installation Code and CSA C22.1 CEC Part I
 - 6. Manufacturer's installation instructions, including required service clearances and venting guidelines
- B. Manufacturer's representative to verify proper and complete installation.

3.2 START-UP

- A. Shall be performed by Raypak factory-trained personnel.
- B. Test during operation and adjust if necessary:
 - 1. Safeties
 - 2. Operating controls
 - 3. Static and full load gas supply pressure
 - 4. Gas manifold and blower air pressure
 - 5. Amp draw of blower
 - 6. Combustion analysis
- C. Submit copy of start-up report to Architect and Engineer.

3.3 TRAINING

- A. Provide factory-authorized service representative to train maintenance personnel on procedures and schedules related to start-up, shut-down, troubleshooting, servicing, and preventive maintenance.
- B. Schedule training at least seven days in advance.

END OF SECTION